



Figure similar

\*\*\*spare part\*\*\* SIPLUS S7-300 CPU 315F-2DP based on 6ES7315-6FF04-0AB0 with conformal coating, -25...+60 °C, fail-safe module with MPI integrated power supply 24 V DC, work memory 384 KB, 40 mm width, 2nd interface DP master/slave Micro Memory Card required

| General information   |  |
|---|--|
| Product type designation                                    | CPU 315F-2 DP  |
| Product function  |  |
| • Isochronous mode  | Yes  |
| Engineering with  |  |
| • Programming package                                       | STEP 7 V5.5 + SP1 or higher or STEP 7 V5.2 + SP1 or higher with HSP 218 + Distributed Safety |
| Supply voltage  |  |
| Rated value (DC)  | 24 V; A power supply according to EN 50155 shall be used                                     |
| permissible range, lower limit (DC)                         | 19.2 V   |
| permissible range, upper limit (DC)                         | 28.8 V   |
| external protection for power supply lines (recommendation) | 2 A min.   |
| Mains buffering   |  |
| • Mains/voltage failure stored energy time                  | 5 ms   |
| • Repeat rate, min.   | 1 s  |
| Input current   |  |
| Current consumption (rated value)                           | 850 mA   |
| Current consumption (in no-load operation), typ.            | 150 mA   |
| Inrush current, typ.  | 3.5 A  |
| I <sup>2</sup> t  | 1 A <sup>2</sup> ·s  |
| Power loss  |  |
| Power loss, typ.  | 4.5 W  |
| Memory  |  |
| Work memory   |  |
| • integrated  | 384 kbyte  |
| • expandable  | No   |
| Load memory   |  |
| • Plug-in (MMC)   | Yes  |
| • Plug-in (MMC), max.                                       | 8 Mbyte  |
| • Data management on MMC (after last programming), min.     | 10 a   |
| Backup  |  |
| • present   | Yes; Guaranteed by MMC (maintenance-free)  |
| • without battery   | Yes; Program and data  |
| CPU processing times  |  |
| for bit operations, typ.                                    | 0.05 μs  |
| for word operations, typ.                                   | 0.09 μs  |
| for fixed point arithmetic, typ.                            | 0.12 μs  |

|   |   |
|---|---|
| for floating point arithmetic, typ.                       | 0.45 $\mu$ s  |
| <b>CPU-blocks</b>   |   |
| Number of blocks (total)                                  | 1 024; (DBs, FCs, FBs); the maximum number of loadable blocks can be reduced by the MMC used. |
| <b>DB</b>   |   |
| • Number, max.  | 1 024; Number range: 1 to 16000   |
| • Size, max.  | 64 kbyte  |
| <b>FB</b>   |   |
| • Number, max.  | 1 024; Number range: 0 to 7999  |
| • Size, max.  | 64 kbyte  |
| <b>FC</b>   |   |
| • Number, max.  | 1 024; Number range: 0 to 7999  |
| • Size, max.  | 64 kbyte  |
| <b>OB</b>   |   |
| • Number, max.  | see instruction list  |
| • Size, max.  | 64 kbyte  |
| • Number of free cycle OBs                                | 1; OB 1   |
| • Number of time alarm OBs                                | 1; OB 10  |
| • Number of delay alarm OBs                               | 2; OB 20, 21  |
| • Number of cyclic interrupt OBs                          | 4; OB 32, 33, 34, 35  |
| • Number of process alarm OBs                             | 1; OB 40  |
| • Number of DPV1 alarm OBs                                | 3; OB 55, 56, 57  |
| • Number of isochronous mode OBs                          | 1; OB 61  |
| • Number of startup OBs                                   | 1; OB 100   |
| • Number of asynchronous error OBs                        | 5; OB 80, 82, 85, 86, 87  |
| • Number of synchronous error OBs                         | 2; OB 121, 122  |
| <b>Nesting depth</b>                                      |   |
| • per priority class                                      | 16  |
| • additional within an error OB                           | 4   |
| <b>Counters, timers and their retentivity</b>             |   |
| <b>S7 counter</b>   |   |
| • Number  | 256   |
| <b>Retentivity</b>  |   |
| — adjustable  | Yes   |
| — preset  | Z 0 to Z 7  |
| <b>Counting range</b>                                     |   |
| — adjustable  | Yes   |
| — lower limit   | 0   |
| — upper limit   | 999   |
| <b>IEC counter</b>  |   |
| • present   | Yes   |
| • Type  | SFB   |
| • Number  | Unlimited (limited only by RAM capacity)  |
| <b>S7 times</b>   |   |
| • Number  | 256   |
| <b>Retentivity</b>  |   |
| — adjustable  | Yes   |
| — preset  | No retentivity  |
| <b>Time range</b>   |   |
| — lower limit   | 10 ms   |
| — upper limit   | 9 990 s   |
| <b>IEC timer</b>  |   |
| • present   | Yes   |
| • Type  | SFB   |
| • Number  | Unlimited (limited only by RAM capacity)  |
| <b>Data areas and their retentivity</b>                   |   |
| Retentive data area (incl. timers, counters, flags), max. | 128 kbyte   |
| <b>Flag</b>   |   |
| • Size, max.  | 2 048 byte  |

|   |   |
|---|---|
| <ul style="list-style-type: none"> <li>• Retentivity available</li> <li>• Retentivity preset</li> <li>• Number of clock memories</li> </ul>   | <p>Yes; MB 0 to MB 2 047</p> <p>MB 0 to MB 15</p> <p>8; 1 memory byte</p>   |
| <b>Data blocks</b>  |   |
| <ul style="list-style-type: none"> <li>• Retentivity adjustable</li> <li>• Retentivity preset</li> </ul>  | <p>Yes; via non-retain property on DB</p> <p>Yes</p>  |
| <b>Local data</b>   |   |
| <ul style="list-style-type: none"> <li>• per priority class, max.</li> </ul>  | 32 kbyte; Max. 2 KB per block   |
| <b>Address area</b>   |   |
| <b>I/O address area</b>   |   |
| <ul style="list-style-type: none"> <li>• Inputs</li> <li>• Outputs</li> </ul>   | <p>2 048 byte</p> <p>2 048 byte</p>   |
| of which distributed  |   |
| <ul style="list-style-type: none"> <li>— Inputs</li> <li>— Outputs</li> </ul>   | <p>2 048 byte</p> <p>2 048 byte</p>   |
| <b>Process image</b>  |   |
| <ul style="list-style-type: none"> <li>• Inputs</li> <li>• Outputs</li> <li>• Inputs, adjustable</li> <li>• Outputs, adjustable</li> <li>• Inputs, default</li> <li>• Outputs, default</li> </ul>   | <p>2 048 byte</p> <p>2 048 byte</p> <p>2 048 byte</p> <p>2 048 byte</p> <p>384 byte</p> <p>384 byte</p>   |
| <b>Subprocess images</b>  |   |
| <ul style="list-style-type: none"> <li>• Number of subprocess images, max.</li> </ul>   | 1   |
| <b>Digital channels</b>   |   |
| <ul style="list-style-type: none"> <li>• Inputs <ul style="list-style-type: none"> <li>— of which central</li> </ul> </li> <li>• Outputs <ul style="list-style-type: none"> <li>— of which central</li> </ul> </li> </ul>                           | <p>16 384</p> <p>1 024</p> <p>16 384</p> <p>1 024</p>   |
| <b>Analog channels</b>  |   |
| <ul style="list-style-type: none"> <li>• Inputs <ul style="list-style-type: none"> <li>— of which central</li> </ul> </li> <li>• Outputs <ul style="list-style-type: none"> <li>— of which central</li> </ul> </li> </ul>                           | <p>1 024</p> <p>256</p> <p>1 024</p> <p>256</p>   |
| <b>Hardware configuration</b>   |   |
| Number of expansion units, max.   | 3   |
| <b>Number of DP masters</b>   |   |
| <ul style="list-style-type: none"> <li>• integrated</li> <li>• via CP</li> </ul>  | <p>1</p> <p>4</p>   |
| <b>Number of operable FMs and CPs (recommended)</b>   |   |
| <ul style="list-style-type: none"> <li>• FM</li> <li>• CP, PtP</li> <li>• CP, LAN</li> </ul>  | <p>8</p> <p>8</p> <p>10</p>   |
| <b>Rack</b>   |   |
| <ul style="list-style-type: none"> <li>• Racks, max.</li> <li>• Modules per rack, max.</li> </ul>   | <p>4</p> <p>8</p>   |
| <b>Time of day</b>  |   |
| <b>Clock</b>  |   |
| <ul style="list-style-type: none"> <li>• Hardware clock (real-time)</li> <li>• retentive and synchronizable</li> <li>• Backup time</li> <li>• Deviation per day, max.</li> <li>• Behavior of the clock following expiry of backup period</li> </ul> | <p>Yes</p> <p>Yes</p> <p>6 wk; At 40 °C ambient temperature</p> <p>10 s; Typ.: 2 s</p> <p>the clock continues at the time of day it had when power was switched off</p> |
| <b>Operating hours counter</b>  |   |
| <ul style="list-style-type: none"> <li>• Number</li> <li>• Number/Number range</li> <li>• Range of values</li> <li>• Granularity</li> <li>• retentive</li> </ul>  | <p>1</p> <p>0</p> <p>0 to 2<sup>31</sup> hours (when using SFC 101)</p> <p>1 h</p> <p>Yes; Must be restarted at each restart</p>  |

|                              |                                     |
|------------------------------|-------------------------------------|
| <b>Clock synchronization</b> |                                     |
| • supported                  | Yes                                 |
| • to MPI, master             | Yes                                 |
| • on MPI, device             | Yes                                 |
| • to DP, master              | Yes; With DP slave only slave clock |
| • on DP, device              | Yes                                 |
| • in AS, master              | Yes                                 |

|                       |  |
|-----------------------|--|
| <b>Digital inputs</b> |  |
|-----------------------|--|

|                          |   |
|--------------------------|---|
| Number of digital inputs | 0 |
|--------------------------|---|

|                        |  |
|------------------------|--|
| <b>Digital outputs</b> |  |
|------------------------|--|

|                           |   |
|---------------------------|---|
| Number of digital outputs | 0 |
|---------------------------|---|

|                      |  |
|----------------------|--|
| <b>Analog inputs</b> |  |
|----------------------|--|

|                         |   |
|-------------------------|---|
| Number of analog inputs | 0 |
|-------------------------|---|

|                   |  |
|-------------------|--|
| <b>Interfaces</b> |  |
|-------------------|--|

|                               |   |
|-------------------------------|---|
| Number of PROFINET interfaces | 0 |
|-------------------------------|---|

|                             |   |
|-----------------------------|---|
| Number of RS 485 interfaces | 2 |
|-----------------------------|---|

|                             |   |
|-----------------------------|---|
| Number of RS 422 interfaces | 0 |
|-----------------------------|---|

|                     |  |
|---------------------|--|
| <b>1. Interface</b> |  |
|---------------------|--|

|                |                             |
|----------------|-----------------------------|
| Interface type | Integrated RS 485 interface |
|----------------|-----------------------------|

|          |    |
|----------|----|
| Isolated | No |
|----------|----|

|                        |  |
|------------------------|--|
| <b>Interface types</b> |  |
|------------------------|--|

|          |     |
|----------|-----|
| • RS 485 | Yes |
|----------|-----|

|   |        |
|---|--------|
| • Output current of the interface, max. | 200 mA |
|---|--------|

|                  |  |
|------------------|--|
| <b>Protocols</b> |  |
|------------------|--|

|       |     |
|-------|-----|
| • MPI | Yes |
|-------|-----|

|                      |    |
|----------------------|----|
| • PROFIBUS DP master | No |
|----------------------|----|

|                      |    |
|----------------------|----|
| • PROFIBUS DP device | No |
|----------------------|----|

|                             |    |
|-----------------------------|----|
| • Point-to-point connection | No |
|-----------------------------|----|

|            |  |
|------------|--|
| <b>MPI</b> |  |
|------------|--|

|                           |              |
|---------------------------|--------------|
| • Transmission rate, max. | 187.5 kbit/s |
|---------------------------|--------------|

|                 |  |
|-----------------|--|
| <b>Services</b> |  |
|-----------------|--|

|                       |     |
|-----------------------|-----|
| — PG/OP communication | Yes |
|-----------------------|-----|

|           |     |
|-----------|-----|
| — Routing | Yes |
|-----------|-----|

|                             |     |
|-----------------------------|-----|
| — Global data communication | Yes |
|-----------------------------|-----|

|                          |     |
|--------------------------|-----|
| — S7 basic communication | Yes |
|--------------------------|-----|

|                    |     |
|--------------------|-----|
| — S7 communication | Yes |
|--------------------|-----|

|                               |    |
|-------------------------------|----|
| — S7 communication, as client | No |
|-------------------------------|----|

|                               |     |
|-------------------------------|-----|
| — S7 communication, as server | Yes |
|-------------------------------|-----|

|                     |  |
|---------------------|--|
| <b>2. Interface</b> |  |
|---------------------|--|

|                |                             |
|----------------|-----------------------------|
| Interface type | Integrated RS 485 interface |
|----------------|-----------------------------|

|          |     |
|----------|-----|
| Isolated | Yes |
|----------|-----|

|                        |  |
|------------------------|--|
| <b>Interface types</b> |  |
|------------------------|--|

|          |     |
|----------|-----|
| • RS 485 | Yes |
|----------|-----|

|   |        |
|---|--------|
| • Output current of the interface, max. | 200 mA |
|---|--------|

|                  |  |
|------------------|--|
| <b>Protocols</b> |  |
|------------------|--|

|       |    |
|-------|----|
| • MPI | No |
|-------|----|

|                      |     |
|----------------------|-----|
| • PROFIBUS DP master | Yes |
|----------------------|-----|

|                      |     |
|----------------------|-----|
| • PROFIBUS DP device | Yes |
|----------------------|-----|

|                             |    |
|-----------------------------|----|
| • Point-to-point connection | No |
|-----------------------------|----|

|                           |  |
|---------------------------|--|
| <b>PROFIBUS DP master</b> |  |
|---------------------------|--|

|                           |           |
|---------------------------|-----------|
| • Transmission rate, max. | 12 Mbit/s |
|---------------------------|-----------|

|                             |                  |
|-----------------------------|------------------|
| • max. number of DP devices | 124; Per station |
|-----------------------------|------------------|

|                 |  |
|-----------------|--|
| <b>Services</b> |  |
|-----------------|--|

|                       |     |
|-----------------------|-----|
| — PG/OP communication | Yes |
|-----------------------|-----|

|           |     |
|-----------|-----|
| — Routing | Yes |
|-----------|-----|

|                             |    |
|-----------------------------|----|
| — Global data communication | No |
|-----------------------------|----|

|                          |                    |
|--------------------------|--------------------|
| — S7 basic communication | Yes; I blocks only |
|--------------------------|--------------------|

|                    |     |
|--------------------|-----|
| — S7 communication | Yes |
|--------------------|-----|

|                               |    |
|-------------------------------|----|
| — S7 communication, as client | No |
|-------------------------------|----|

|  |  |
|--|--|
| — S7 communication, as server  | Yes  |
| — Equidistance   | Yes  |
| — Isochronous mode   | Yes; OB 61   |
| — SYNC/FREEZE  | Yes  |
| — activation/deactivation of DP devices  | Yes  |
| — max. number of DP devices that can be activated/deactivated at the same time | 8  |
| — DPV1   | Yes  |
| <b>Address area</b>  |  |
| — Inputs, max.   | 2 048 byte   |
| — Outputs, max.  | 2 048 byte   |
| <b>User data per DP device</b>   |  |
| — Inputs, max.   | 244 byte   |
| — Outputs, max.  | 244 byte   |
| <b>PROFIBUS DP device</b>  |  |
| • GSD file   | The latest GSD file is available at: <a href="http://www.siemens.com/profibus-gsd">http://www.siemens.com/profibus-gsd</a> |
| • Transmission rate, max.  | 12 Mbit/s  |
| • automatic baud rate search   | Yes; only with passive interface   |
| • Address area, max.   | 32   |
| • User data per address area, max.   | 32 byte  |
| <b>Services</b>  |  |
| — PG/OP communication  | Yes  |
| — Routing  | Yes; Only with active interface  |
| — Global data communication  | No   |
| — S7 basic communication   | No   |
| — S7 communication   | Yes; Only server, configured on one side   |
| — S7 communication, as client  | No   |
| — S7 communication, as server  | Yes  |
| — Direct data exchange (slave-to-slave communication)                          | Yes  |
| — DPV1   | No   |
| <b>Transfer memory</b>   |  |
| — Inputs   | 244 byte   |
| — Outputs  | 244 byte   |
| <b>Protocols</b>   |  |
| PROFIsafe  | Yes  |
| <b>Communication functions</b>   |  |
| PG/OP communication  | Yes  |
| Data record routing  | Yes  |
| <b>Global data communication</b>   |  |
| • supported  | Yes  |
| • Number of GD loops, max.   | 8  |
| • Number of GD packets, max.   | 8  |
| • Number of GD packets, transmitter, max.                                      | 8  |
| • Number of GD packets, receiver, max.   | 8  |
| • Size of GD packets, max.   | 22 byte  |
| • Size of GD packet (of which consistent), max.                                | 22 byte  |
| <b>S7 basic communication</b>  |  |
| • supported  | Yes  |
| • User data per job, max.  | 76 byte  |
| • User data per job (of which consistent), max.                                | 76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or X_GET as server)   |
| <b>S7 communication</b>  |  |
| • supported  | Yes  |
| • as server  | Yes  |
| • as client  | Yes; Via CP and loadable FB  |
| • User data per job, max.  | 180 byte; With PUT/GET   |
| • User data per job (of which consistent), max.                                | 240 byte; as server  |
| <b>S5 compatible communication</b>   |  |
| • supported  | Yes; via CP and loadable FC  |

|  |  |
|--|--|
| <b>Number of connections</b>                         |  |
| • overall  | 16   |
| • usable for PG communication                        | 15   |
| — reserved for PG communication                      | 1  |
| — adjustable for PG communication, min.              | 1  |
| — adjustable for PG communication, max.              | 15   |
| • usable for OP communication                        | 15   |
| — reserved for OP communication                      | 1  |
| — adjustable for OP communication, min.              | 1  |
| — adjustable for OP communication, max.              | 15   |
| • usable for S7 basic communication                  | 12   |
| — reserved for S7 basic communication                | 0  |
| — adjustable for S7 basic communication, min.        | 0  |
| — adjustable for S7 basic communication, max.        | 12   |
| <b>S7 message functions</b>                          |  |
| Number of login stations for message functions, max. | 16; Depending on the configured connections for PG/OP and S7 basic communication   |
| Process diagnostic messages                          | Yes  |
| simultaneously active Alarm_S blocks, max.           | 300  |
| <b>Test commissioning functions</b>                  |  |
| Status block   | Yes; Up to 2 simultaneously  |
| Single step  | Yes  |
| Number of breakpoints                                | 4  |
| <b>Status/control</b>                                |  |
| • Status/control variable                            | Yes  |
| • Variables  | Inputs, outputs, memory bits, DB, times, counters  |
| • Number of variables, max.                          | 30   |
| — of which status variables, max.                    | 30   |
| — of which control variables, max.                   | 14   |
| <b>Forcing</b>                                       |  |
| • Forcing  | Yes  |
| • Forcing, variables                                 | Inputs, outputs  |
| • Number of variables, max.                          | 10   |
| <b>Diagnostic buffer</b>                             |  |
| • present  | Yes  |
| • Number of entries, max.                            | 500  |
| — adjustable   | No   |
| — of which powerfail-proof                           | 100; Only the last 100 entries are retained  |
| • Number of entries readable in RUN, max.            |  |
| — adjustable   | Yes; From 10 to 499  |
| — preset   | 10   |
| <b>Isolation</b>                                     |  |
| Isolation tested with                                | 500 V AC for 1 minute  |
| <b>Standards, approvals, certificates</b>            |  |
| CE mark  | Yes  |
| UL approval  | Yes; File E239877  |
| RCM (formerly C-TICK)                                | Yes  |
| KC approval  | Yes  |
| EAC (formerly Gost-R)                                | Yes  |
| <b>Use in hazardous areas</b>                        |  |
| • ATEX   | Yes  |
| <b>Railway application</b>                           |  |
| • EN 50155   | Yes; Sections 4, 5 and 12; no further agreements apply; T1, Category 1, Class A/B, EN 50155:2007                               |
| <b>Ambient conditions</b>                            |  |
| <b>Ambient temperature during operation</b>          |  |
| • min.   | -25 °C; = Tmin   |
| • max.   | 60 °C; = Tmax; the rated temperature range of -25 ... +55 °C (T1) applies for the use on railway vehicles according to EN50155 |

|   |  |
|---|--|
| <b>Ambient temperature during storage/transportation</b>  |  |
| • min.  | -40 °C   |
| • max.  | 70 °C  |
| <b>Altitude during operation relating to sea level</b>  |  |
| • Installation altitude above sea level, max.   | 2 000 m  |
| • Ambient air temperature-barometric pressure-altitude  | Tmin ... Tmax at 1 140 hPa ... 795 hPa (-1 000 m ... +2 000 m)                                     |
| <b>Relative humidity</b>  |  |
| • With condensation, tested in accordance with IEC 60068-2-38, max.   | 100 %; RH incl. condensation/frost (no commissioning under condensation conditions)                |
| <b>Resistance</b>   |  |
| <b>Use in stationary industrial systems</b>   |  |
| — to biologically active substances according to EN 60721-3-3   | Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request |
| — to chemically active substances according to EN 60721-3-3   | Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *           |
| — to mechanically active substances according to EN 60721-3-3   | Yes; Class 3S4 incl. sand, dust; *   |
| <b>Use on land craft, rail vehicles and special-purpose vehicles</b>  |  |
| — to biologically active substances according to EN 60721-3-5   | Yes; Class 5B2 mold, fungus and dry rot spores (with the exception of fauna); Class 5B3 on request |
| — to chemically active substances according to EN 60721-3-5   | Yes; Class 5C3 (RH < 75 %) incl. salt spray acc. to EN 50155 (ST2); *                              |
| — to mechanically active substances according to EN 60721-3-5   | Yes; Class 5S3 incl. sand, dust; *   |
| <b>Remark</b>   |  |
| — Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04 | * The supplied plug covers must remain in place over the unused interfaces during operation!       |

### Configuration

|   |  |
|---|--|
| <b>Configuration software</b>                 |  |
| • STEP 7                                      | Yes; V5.2 SP1 or higher with HW update |
| <b>Programming</b>                            |  |
| • Command set                                 | see instruction list                   |
| • Nesting levels                              | 8                                      |
| • System functions (SFC)                      | see instruction list                   |
| • System function blocks (SFB)                | see instruction list                   |
| <b>Programming language</b>                   |  |
| — LAD   | Yes                                    |
| — FBD   | Yes                                    |
| — STL   | Yes                                    |
| — SCL   | Yes                                    |
| — CFC   | Yes                                    |
| — GRAPH                                       | Yes                                    |
| — HiGraph®                                    | Yes                                    |
| <b>Know-how protection</b>                    |  |
| • User program protection/password protection | Yes                                    |
| • Block encryption                            | Yes; With S7 block Privacy             |

### Dimensions

|        |        |
|--------|--------|
| Width  | 40 mm  |
| Height | 125 mm |
| Depth  | 130 mm |

### Weights

|                 |       |
|-----------------|-------|
| Weight, approx. | 290 g |
|-----------------|-------|

### Classifications

|        | Version | Classification |
|--------|---------|----------------|
| eClass | 14      | 27-24-22-07    |
| eClass | 12      | 27-24-22-07    |
| eClass | 9.1     | 27-24-22-07    |
| eClass | 9       | 27-24-22-07    |
| eClass | 8       | 27-24-22-07    |

|        |     |             |
|--------|-----|-------------|
| eClass | 7.1 | 27-24-22-07 |
| eClass | 6   | 27-24-22-07 |
| ETIM   | 10  | EC000236    |
| ETIM   | 9   | EC000236    |
| ETIM   | 8   | EC000236    |
| ETIM   | 7   | EC000236    |
| IDEA   | 4   | 3565        |
| UNSPSC | 15  | 32-15-17-05 |

**Approvals / Certificates**

**General Product Approval**

[Miscellaneous](#)



[Manufacturer Declaration](#)

[Declaration of Conformity](#)

[China RoHS](#)

[TUEV](#)

**General Product Approval**

**EMV**

**For use in hazardous locations**

**Test Certificates**



[CCC-Ex](#)

[TUEV](#)

last modified:

12/8/2024