

### product type designation



Figure similar

### CM 1243-5 RAIL

SIPLUS S7-1200 CM 1243-5 T1 rail based on 6GK7243-5DX30-0XE0 with conformal coating, -25...+55 °C, OT1 with ST1/2 (+70 °C für 10 minutes), communications module CM 1243-5 for connecting S7-1200 to PROFIBUS as DP master module

Technical Product Detail Page

<https://l.siemens.com/1P6AG2243-5DX30-1XE0>

### transfer rate

transfer rate

- at the 1st interface / according to PROFIBUS

9.6 kbit/s ... 12 Mbit/s

### interfaces

number of interfaces / according to Industrial Ethernet

0

number of electrical connections

- at the 1st interface / according to PROFIBUS
- for power supply

1

1

type of electrical connection

- at the 1st interface / according to PROFIBUS
- for power supply

9-pin Sub-D socket (RS485)

3-pole terminal block

### supply voltage, current consumption, power loss

type of voltage / of the supply voltage

DC

supply voltage / external

24 V

supply voltage / external / at DC / rated value

24 V

relative positive tolerance / at DC / at 24 V

20 %

relative negative tolerance / at DC / at 24 V

20 %

consumed current

- from external supply voltage / at DC / at 24 V / typical

0.1 A

power loss [W]

2.4 W

### ambient conditions

ambient temperature

- during operation
- during storage
- during transport
- note

-25 ... +55 °C

-40 ... +70 °C

-40 ... +70 °C

+70 °C for 10 min (OT1, ST1/ST2 according to EN 50155)

installation altitude / at height above sea level / maximum

2000 m

ambient condition / relating to ambient temperature - air pressure - installation altitude

Tmin ... Tmax at 1 140 hPa ... 795 hPa (-1 000 m ... +2 000 m)

relative humidity

- with condensation / according to IEC 60068-2-38 / maximum

100 %; RH including condensation/frost (no commissioning when condensation is present), horizontal installation

chemical resistance / to commercially available cooling lubricants

Yes; incl. airborne diesel and oil droplets

resistance to biologically active substances

- conformity according to EN 60721-3-3

Yes; Class 3B2 mold and fungal spores (excluding fauna), Class 3B3 on request

|   |   |
|---|---|
| <ul style="list-style-type: none"> <li>conformity according to EN 60721-3-5</li> </ul>  | Yes; Class 5B2 mold and fungal spores (excluding fauna), Class 5B3 on request   |
| <p>resistance to chemically active substances</p> <ul style="list-style-type: none"> <li>conformity according to EN 60721-3-3</li> <li>conformity according to EN 60721-3-5</li> </ul>  | <p>Yes; Class 3C4 (RH &lt; 75 %) incl. salt spray in accordance with EN 60068-2-52 (Severity 3). The supplied plug covers must remain in place on the unused interfaces during operation.</p> <p>Yes; Class 5C3 (RH &lt; 75%) including salt spray acc. to EN 60068-2-52 (Severity level 3). The supplied plug covers must remain in place over the unused interfaces during operation!</p> |
| <p>resistance to mechanically active substances</p> <ul style="list-style-type: none"> <li>conformity according to EN 60721-3-3</li> <li>conformity according to EN 60721-3-5</li> </ul>  | <p>Yes; Class 3S4 incl. sand, dust. The supplied plug covers must remain in place over the unused interfaces during operation.</p> <p>Yes; Class 5S3 incl. sand, dust. The supplied plug covers must remain in place over the unused interfaces during operation!</p>   |
| coating / for equipped printed circuit board / according to EN 61086  | Yes; Class 2 for high availability  |
| type of coating / protection against pollution according to EN 60664-3  | Yes; Protection of the type 1   |
| type of coating / for electronic devices in railway applications according to EN 50155  | Yes; Protective coating of the Class PC2 according to EN 50155:2018   |
| type of test / of the coating / according to MIL-I-46058C   | Yes; Coating discoloration during service life possible   |
| product conformity / of the coating / Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC-CC-830A   | Yes; Conformal coating, class A   |
| protection class IP   | IP20  |
| <b>design, dimensions and weights</b>   |   |
| module format   | Compact module S7-1200 single width   |
| width   | 30 mm   |
| height  | 100 mm  |
| depth   | 75 mm   |
| net weight  | 0.134 kg  |
| fastening method  |   |
| <ul style="list-style-type: none"> <li>35 mm DIN-rail mounting</li> <li>S7-300 rail mounting</li> <li>wall mounting</li> </ul>  | <p>Yes</p> <p>No</p> <p>Yes</p>   |
| <b>product features, product functions, product components / general</b>  |   |
| number of units   |   |
| <ul style="list-style-type: none"> <li>per CPU / maximum</li> </ul>   | 3   |
| <b>performance data / PROFIBUS DP</b>   |   |
| service / as DP master  |   |
| <ul style="list-style-type: none"> <li>DPV1</li> </ul>  | Yes   |
| number of DP devices  |   |
| <ul style="list-style-type: none"> <li>on DP master / operable</li> </ul>   | 32  |
| data volume   |   |
| <ul style="list-style-type: none"> <li>of the address range of the inputs / as DP master / total</li> <li>of the address range of the outputs / as DP master / total</li> <li>of the address range of the inputs / per DP device</li> <li>of the address range of the outputs / per DP device</li> <li>of the address range of the diagnostic data / per DP device</li> </ul> | <p>512 byte</p> <p>512 byte</p> <p>244 byte</p> <p>244 byte</p> <p>240 byte</p>   |
| service / as DP device  |   |
| <ul style="list-style-type: none"> <li>DPV0</li> <li>DPV1</li> </ul>  | <p>No</p> <p>No</p>   |
| <b>performance data / S7 communication</b>  |   |
| number of possible connections / for S7 communication   |   |
| <ul style="list-style-type: none"> <li>maximum</li> <li>with PG connections / maximum</li> <li>with PG/OP connections / maximum</li> </ul>  | <p>8; max. 4 connections to other S7 stations</p> <p>1</p> <p>3</p>   |
| <b>performance data / multi-protocol mode</b>   |   |
| number of active connections / with multi-protocol mode   |   |
| <ul style="list-style-type: none"> <li>without DP / maximum</li> <li>with DP / maximum</li> </ul>   | <p>8</p> <p>8</p>   |

| performance data / telecontrol   |  |         |
|--|--|---------|
| protocol / is supported<br>• TCP/IP  | No   |         |
| product functions / management, configuration, engineering   |  |         |
| configuration software<br>• required   | STEP 7 Basic/Professional  |         |
| product function / is supported / identification link  | Yes; acc. to IEC 61406-1:2022  |         |
| product functions / position detection   |  |         |
| certificate of suitability / railway application in accordance with EN 50121-3-2   | Yes; EMC for railway vehicles  |         |
| certificate of suitability / railway application in accordance with EN 50121-4   | Yes; EMC for signaling and telecommunications equipment  |         |
| certificate of suitability / railway application in accordance with EN 50124-1   | Yes; Railway applications - Overvoltage category OV2 pollution degree PD2 rated impulse voltage UNi = 0.5 kVUNm = DC 24  |         |
| certificate of suitability / railway application in accordance with EN 50125-1   | Yes; Railway vehicles - See ambient conditions   |         |
| certificate of suitability / railway application in accordance with EN 50125-2   | Yes; Fixed-electrical installations - see ambient conditions   |         |
| certificate of suitability / railway application in accordance with EN 50125-3   | Yes; Signal and telecommunications equipment - see Ambient conditions vibrations and shocks: Application point outside the rails (distance 1 m to 3 m from rail)   |         |
| certificate of suitability / railway application in accordance with EN 50155   | Yes; Railway vehicles - temperature class OT1, ST1/ST2, horizontal mounting position   |         |
| certificate of suitability / railway application in accordance with EN 61373   | Yes; Railway vehicles - Vibrations and shocks Category 1 Class A/B   |         |
| certificate of suitability / fire protection in accordance with EN 45545-2   | Yes; Railway vehicles - for proof, see Service & Support   |         |
| further information / internet links   |  |         |
| internet link<br>• to website: Selection guide for cables and connectors<br>• to web page: selection aid TIA Selection Tool<br>• to website: Industrial communication<br>• to web page: SiePortal<br>• to website: Image database<br>• to website: CAx-Download-Manager<br>• to website: Industry Online Support | <a href="https://support.industry.siemens.com/cs/ww/en/view/109766358">https://support.industry.siemens.com/cs/ww/en/view/109766358</a><br><a href="https://www.siemens.com/tstcloud">https://www.siemens.com/tstcloud</a><br><a href="https://www.siemens.com/simatic-net">https://www.siemens.com/simatic-net</a><br><a href="https://sieportal.siemens.com/">https://sieportal.siemens.com/</a><br><a href="https://www.automation.siemens.com/bilddb">https://www.automation.siemens.com/bilddb</a><br><a href="https://siemens.com/cax">https://siemens.com/cax</a><br><a href="https://support.industry.siemens.com">https://support.industry.siemens.com</a>  |         |
| security information   |  |         |
| security information   | Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement - and continuously maintain - a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit <a href="http://www.siemens.com/cybersecurity-industry">www.siemens.com/cybersecurity-industry</a> . Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under <a href="https://www.siemens.com/cert">https://www.siemens.com/cert</a> . (V4.7) |         |
| Approvals / Certificates   |  |         |
| General Product Approval   |  |         |
| <a href="#">Manufacturer Declaration</a>   |       |         |
| General Product Approval   | EMV  | Railway |



[China RoHS](#)



[Confirmation](#)

---

last modified:

3/10/2026