



SIMATIC HMI connection box compact for Mobile Panels, installation in control cabinet, PROFINET and PROFI-safe, connection of safety relay, Connection point detection

General information	
Product type designation	Connection box
Product function	
<ul style="list-style-type: none"> • Web-based management 	No
FH technology	
Safety evaluation through direct wiring	
<ul style="list-style-type: none"> • Reconnection without emergency stop circuit interruption • Reconnection with emergency stop circuit interruption • Monitoring the STOP button • Monitoring of emergency stop button • Monitoring of acknowledgement button 	<p>No</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p>
Safety evaluation via PROFI-safe	
<ul style="list-style-type: none"> • Reconnection without emergency stop circuit interruption • Reconnection with emergency stop circuit interruption • Monitoring the STOP button • Monitoring of emergency stop button • Monitoring of acknowledgement button 	<p>Yes</p> <p>No</p> <p>Yes</p> <p>Yes</p> <p>Yes</p>
Installation type/mounting	
Wall mounting/direct mounting	No
Control cabinet installation	Yes
Supply voltage	
Type of supply voltage	DC
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Input current	
Current consumption (rated value)	18 mA
Starting current inrush I ² t	0.003 A ² ·s
Power	
Active power input, typ.	0.43 W
Interfaces	
Number of industrial Ethernet interfaces	2
Number of PROFINET interfaces	2
Connection point identification	Yes
Industrial Ethernet	
<ul style="list-style-type: none"> • Industrial Ethernet status LED 	0
Protocols	
PROFINET	Yes; No switch functionality
IRT	No

PROFIsafe	Yes; No switch functionality
EtherNet/IP	Yes
AS-Interface	No
EIB/KNX	No
Protocols (Ethernet)	
• TCP/IP	Yes; No switch functionality
• DHCP	No
• SNMP	No
• DCP	No
• LLDP	No
Redundancy mode	
Media redundancy	
— MRP	No
Further protocols	
• MODBUS	Yes
• other bus systems	No
EMC	
Emission of radio interference acc. to EN 55 011	
• Limit class A, for use in industrial areas	Yes; EN 61000-6-4, interference emission: Intended for use in industrial areas.
• Limit class B, for use in residential areas	No
Degree and class of protection	
IP (at the front)	IP65
IP (rear)	IP20
Standards, approvals, certificates	
CE mark	Yes
cULus	Yes
RCM (formerly C-TICK)	Yes
KC approval	No; in preparation
Suitable for safety functions	Yes
Highest safety class achievable in safety mode	
• Performance level according to ISO 13849-1	PLe
• SIL acc. to IEC 61508	SIL 3
Use in hazardous areas	
• ATEX Zone 2	No
• ATEX Zone 22	No
• cULus Class I Zone 1	No
• cULus Class I Zone 2, Division 2	No
• FM Class I Division 2	No
Marine approval	
• Germanischer Lloyd (GL)	Yes
• American Bureau of Shipping (ABS)	Yes
• Bureau Veritas (BV)	Yes
• Det Norske Veritas (DNV)	Yes
• Korean Register of Shipping (KRS)	Yes
• Lloyds Register of Shipping (LRS)	Yes
• Nippon Kaiji Kyokai (Class NK)	Yes
• Polski Rejestr Statkow (PRS)	No
• Chinese Classification Society (CCS)	Yes
Ambient conditions	
Ambient temperature during operation	
• min.	0 °C
• max.	55 °C
Relative humidity	
• Operation, max.	90 %
Configuration	
Configuration software	
• STEP 7 Professional (TIA Portal)	No
• WinCC Comfort (TIA Portal)	No
• WinCC Advanced (TIA Portal)	No

- WinCC Professional (TIA Portal)

No

Mechanics/material

Enclosure material (front)

- Plastic
- Aluminum
- Stainless steel

Yes
No
No

Dimensions

Width	96 mm
Height	125 mm
Depth	77.9 mm
Mounting cutout, width	78 mm
Mounting cutout, height	107 mm
mounting depth	30 mm

Weights

Weight (without packaging)	0.25 kg
Weight (with packaging)	0.29 kg

Classifications

	Version	Classification
eClass	14	27-33-02-92
eClass	12	27-33-02-92
eClass	9.1	27-33-02-92
eClass	9	27-33-02-92
eClass	8	27-24-92-03
eClass	7.1	27-24-92-03
eClass	6	27-24-92-03
ETIM	10	EC002584
ETIM	9	EC002584
ETIM	8	EC002584
ETIM	7	EC002584
IDEA	4	3552
UNSPSC	15	32-15-17-03

Approvals / Certificates

General Product Approval	other	Environment
--------------------------	-------	-------------



[Confirmation](#)

[Miscellaneous](#)



[Environmental Confirmations](#)

last modified:

2/4/2025