

adapter frame widescreen for 19" touch devices, so that small 19" devices fit into the installation cutout of large 19" widescreen devices, scope of supply: 1 adapter frame including mounting accessories



Figure similar

General information	
Product type designation	Adapter frame 19" touch widescreen
Installation type/mounting	
Mounting in portrait format possible	Yes
Mounting in landscape format possible	Yes
Standards, approvals, certificates	
CE mark	No; No CE marking obligation
REACH	Yes; Tested
RoHS conformity	Yes; Tested / compliant
Use in hazardous areas	
• ATEX Zone 2	No
• ATEX Zone 22	No
• ATEX as target device	No
• IECEx Zone 1	No
• IECEx Zone 11	No
• IECEx Zone 2	No
• IECEx Zone 22	No
• cULus Class I Zone 1	No
• cULus Class I Zone 2, Division 2	No
• cULus Class II Division 2	No
• FM Class I Division 2	No
• FM Class II Division 2	No
Marine approval	
• Germanischer Lloyd (GL)	No
• American Bureau of Shipping (ABS)	No
• Bureau Veritas (BV)	No
• Det Norske Veritas (DNV)	No
• Korean Register of Shipping (KRS)	No
• Lloyds Register of Shipping (LRS)	No
• Nippon Kaiji Kyokai (Class NK)	No
• Polski Rejestr Statkow (PRS)	No
• Chinese Classification Society (CCS)	No
• Marine approval as target device	No
Ambient conditions	
Suited for indoor use	Yes
Suited for outdoor use	No
Ambient temperature during operation	
• min.	0 °C

• max.	50 °C
Ambient temperature during storage/transportation	
• min.	-20 °C
• max.	60 °C
Relative humidity	
• Operation, max.	90 %

#### Accessories

Function description	mechanical adapter
belongs to product	MTP1900 Unified Comfort, ITC1900 V3

#### Mechanics/material

Enclosure material (front)	
• Aluminum	Yes; Powder-coated

#### Dimensions

Width	480.2 mm
Height	334.2 mm
Depth	33 mm
Mounting cutout, width	465.2 mm; existing mounting cut-out
Mounting cutout, height	319.2 mm; existing mounting cut-out
mounting depth	25 mm

#### Scope of supply

Delivery quantity in pieces	1; Adapter frame 19"
Components included	incl. mounting accessories

#### Other

Merchandise	No
Manufacturer name	SIEMENS AG
Manufacturer's address	Gleiwitzerstraße 555, 90475 Nuremberg, Germany
Note:	observe the user manual

#### Classifications

	Version	Classification
eClass	14	27-33-02-92
eClass	12	27-33-02-92
eClass	9.1	27-33-02-92
eClass	9	27-33-02-92
eClass	8	27-24-92-03
eClass	7.1	27-24-92-03
eClass	6	27-24-92-03
ETIM	10	EC002584
ETIM	9	EC002584
ETIM	8	EC002584
ETIM	7	EC002584

#### Approvals / Certificates

General Product Approval	For use in hazardous locations
--------------------------	--------------------------------



[Miscellaneous](#)

[FM](#)

[CCC-Ex](#)

#### For use in hazardous locations



[Miscellaneous](#)

#### Further information

Usable in the following products: Detailed information can be found in the cross-list, which is available for download in the following SIOS note: 40466415  
<https://support.industry.siemens.com/cs/document/40466415/status-of-the-simatic-hmi-accessories-and-cross-list-update?dti=0&lc=en-WW>

---

last modified:

8/1/2024 