



Figure similar

\*\*\*spare part\*\*\* SIMATIC S7-300, CPU 314 central processing unit with MPI, integrated power supply 24 V DC, work memory 128 KB, Micro Memory Card required

General information	
Product type designation	CPU 314
HW functional status	01
Firmware version	V3.3
Engineering with	
• Programming package	STEP 7 V5.5 + SP1 or higher or STEP 7 V5.2 + SP1 or higher with HSP 218
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
external protection for power supply lines (recommendation)	2 A min.
Mains buffering	
• Mains/voltage failure stored energy time	5 ms
• Repeat rate, min.	1 s
Input current	
Current consumption (rated value)	650 mA
Current consumption (in no-load operation), typ.	140 mA
Inrush current, typ.	3.5 A
$I^2t$	1 A <sup>2</sup> s
Power loss	
Power loss, typ.	4 W
Memory	
Work memory	
• integrated	128 kbyte
• expandable	No
Load memory	
• Plug-in (MMC)	Yes
• Plug-in (MMC), max.	8 Mbyte
• Data management on MMC (after last programming), min.	10 a
Backup	
• present	Yes; Guaranteed by MMC (maintenance-free)
• without battery	Yes; Program and data
CPU processing times	
for bit operations, typ.	0.06 μs
for word operations, typ.	0.12 μs
for fixed point arithmetic, typ.	0.16 μs
for floating point arithmetic, typ.	0.59 μs

**CPU-blocks**

Number of blocks (total)	1 024; (DBs, FCs, FBs); the maximum number of loadable blocks can be reduced by the MMC used.
<b>DB</b>	
• Number, max.	1 024; Number range: 1 to 16000
• Size, max.	64 kbyte
<b>FB</b>	
• Number, max.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
<b>FC</b>	
• Number, max.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
<b>OB</b>	
• Number, max.	see instruction list
• Size, max.	64 kbyte
• Number of free cycle OBs	1; OB 1
• Number of time alarm OBs	1; OB 10
• Number of delay alarm OBs	2; OB 20, 21
• Number of cyclic interrupt OBs	4; OB 32, 33, 34, 35
• Number of process alarm OBs	1; OB 40
• Number of startup OBs	1; OB 100
• Number of asynchronous error OBs	4; OB 80, 82, 85, 87
• Number of synchronous error OBs	2; OB 121, 122
<b>Nesting depth</b>	
• per priority class	16
• additional within an error OB	4
<b>Counters, timers and their retentivity</b>	
<b>S7 counter</b>	
• Number	256
<b>Retentivity</b>	
— adjustable	Yes
— preset	Z 0 to Z 7
<b>Counting range</b>	
— lower limit	0
— upper limit	999
<b>IEC counter</b>	
• present	Yes
• Type	SFB
• Number	Unlimited (limited only by RAM capacity)
<b>S7 times</b>	
• Number	256
<b>Retentivity</b>	
— adjustable	Yes
— preset	No retentivity
<b>Time range</b>	
— lower limit	10 ms
— upper limit	9 990 s
<b>IEC timer</b>	
• present	Yes
• Type	SFB
• Number	Unlimited (limited only by RAM capacity)
<b>Data areas and their retentivity</b>	
Retentive data area (incl. timers, counters, flags), max.	64 kbyte
<b>Flag</b>	
• Size, max.	256 byte
• Retentivity available	Yes; MB 0 to MB 255
• Retentivity preset	MB 0 to MB 15
• Number of clock memories	8; 1 memory byte
<b>Data blocks</b>	

<ul style="list-style-type: none"> <li>• Retentivity adjustable</li> </ul>	Yes; via non-retain property on DB
<ul style="list-style-type: none"> <li>• Retentivity preset</li> </ul>	Yes
<b>Local data</b>	
<ul style="list-style-type: none"> <li>• per priority class, max.</li> </ul>	32 kbyte; Max. 2 KB per block
<b>Address area</b>	
<b>I/O address area</b>	
<ul style="list-style-type: none"> <li>• Inputs</li> </ul>	1 024 byte
<ul style="list-style-type: none"> <li>• Outputs</li> </ul>	1 024 byte
<b>Process image</b>	
<ul style="list-style-type: none"> <li>• Inputs</li> </ul>	1 024 byte
<ul style="list-style-type: none"> <li>• Outputs</li> </ul>	1 024 byte
<ul style="list-style-type: none"> <li>• Inputs, adjustable</li> </ul>	1 024 byte
<ul style="list-style-type: none"> <li>• Outputs, adjustable</li> </ul>	1 024 byte
<ul style="list-style-type: none"> <li>• Inputs, default</li> </ul>	128 byte
<ul style="list-style-type: none"> <li>• Outputs, default</li> </ul>	128 byte
<b>Digital channels</b>	
<ul style="list-style-type: none"> <li>• Inputs</li> </ul>	1 024
<ul style="list-style-type: none"> <li>— of which central</li> </ul>	1 024
<ul style="list-style-type: none"> <li>• Outputs</li> </ul>	1 024
<ul style="list-style-type: none"> <li>— of which central</li> </ul>	1 024
<b>Analog channels</b>	
<ul style="list-style-type: none"> <li>• Inputs</li> </ul>	256
<ul style="list-style-type: none"> <li>— of which central</li> </ul>	256
<ul style="list-style-type: none"> <li>• Outputs</li> </ul>	256
<ul style="list-style-type: none"> <li>— of which central</li> </ul>	256
<b>Hardware configuration</b>	
Number of expansion units, max.	3
<b>Number of DP masters</b>	
<ul style="list-style-type: none"> <li>• integrated</li> </ul>	0
<ul style="list-style-type: none"> <li>• via CP</li> </ul>	4
<b>Number of operable FMs and CPs (recommended)</b>	
<ul style="list-style-type: none"> <li>• FM</li> </ul>	8
<ul style="list-style-type: none"> <li>• CP, PtP</li> </ul>	8
<ul style="list-style-type: none"> <li>• CP, LAN</li> </ul>	10
<b>Rack</b>	
<ul style="list-style-type: none"> <li>• Racks, max.</li> </ul>	4
<ul style="list-style-type: none"> <li>• Modules per rack, max.</li> </ul>	8
<b>Time of day</b>	
<b>Clock</b>	
<ul style="list-style-type: none"> <li>• Hardware clock (real-time)</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• retentive and synchronizable</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Backup time</li> </ul>	6 wk; At 40 °C ambient temperature
<ul style="list-style-type: none"> <li>• Deviation per day, max.</li> </ul>	10 s; Typ.: 2 s
<ul style="list-style-type: none"> <li>• Behavior of the clock following POWER-ON</li> </ul>	Clock continues running after POWER OFF
<ul style="list-style-type: none"> <li>• Behavior of the clock following expiry of backup period</li> </ul>	the clock continues at the time of day it had when power was switched off
<b>Operating hours counter</b>	
<ul style="list-style-type: none"> <li>• Number</li> </ul>	1
<ul style="list-style-type: none"> <li>• Number/Number range</li> </ul>	0
<ul style="list-style-type: none"> <li>• Range of values</li> </ul>	0 to 2 <sup>31</sup> hours (when using SFC 101)
<ul style="list-style-type: none"> <li>• Granularity</li> </ul>	1 h
<ul style="list-style-type: none"> <li>• retentive</li> </ul>	Yes; Must be restarted at each restart
<b>Clock synchronization</b>	
<ul style="list-style-type: none"> <li>• supported</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• to MPI, master</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• on MPI, device</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• in AS, master</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• in AS, device</li> </ul>	No
<b>Digital inputs</b>	
Number of digital inputs	0

Digital outputs	
Number of digital outputs	0
Analog inputs	
Number of analog inputs	0
Interfaces	
Number of PROFINET interfaces	0
Number of RS 485 interfaces	1; MPI
Number of RS 422 interfaces	0
1. Interface	
Interface type	Integrated RS 485 interface
Isolated	No
Interface types	
<ul style="list-style-type: none"> <li>• RS 485</li> <li>• Output current of the interface, max.</li> </ul>	<ul style="list-style-type: none"> <li>Yes</li> <li>200 mA</li> </ul>
Protocols	
<ul style="list-style-type: none"> <li>• MPI</li> <li>• PROFIBUS DP master</li> <li>• PROFIBUS DP device</li> <li>• Point-to-point connection</li> </ul>	<ul style="list-style-type: none"> <li>Yes</li> <li>No</li> <li>No</li> <li>No</li> </ul>
MPI	
<ul style="list-style-type: none"> <li>• Transmission rate, max.</li> </ul>	187.5 kbit/s
Services	
<ul style="list-style-type: none"> <li>— PG/OP communication</li> <li>— Routing</li> <li>— Global data communication</li> <li>— S7 basic communication</li> <li>— S7 communication</li> <li>— S7 communication, as client</li> <li>— S7 communication, as server</li> </ul>	<ul style="list-style-type: none"> <li>Yes</li> <li>No</li> <li>Yes</li> <li>Yes</li> <li>Yes; Only server, configured on one side</li> <li>No</li> <li>Yes</li> </ul>
Protocols	
PROFIsafe	No
Communication functions	
PG/OP communication	Yes
Data record routing	No
Global data communication	
<ul style="list-style-type: none"> <li>• supported</li> <li>• Number of GD loops, max.</li> <li>• Number of GD packets, max.</li> <li>• Number of GD packets, transmitter, max.</li> <li>• Number of GD packets, receiver, max.</li> <li>• Size of GD packets, max.</li> <li>• Size of GD packet (of which consistent), max.</li> </ul>	<ul style="list-style-type: none"> <li>Yes</li> <li>8</li> <li>8</li> <li>8</li> <li>8</li> <li>22 byte</li> <li>22 byte</li> </ul>
S7 basic communication	
<ul style="list-style-type: none"> <li>• supported</li> <li>• User data per job, max.</li> <li>• User data per job (of which consistent), max.</li> </ul>	<ul style="list-style-type: none"> <li>Yes</li> <li>76 byte</li> <li>76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or X_GET as server)</li> </ul>
S7 communication	
<ul style="list-style-type: none"> <li>• supported</li> <li>• as server</li> <li>• as client</li> <li>• User data per job, max.</li> <li>• User data per job (of which consistent), max.</li> </ul>	<ul style="list-style-type: none"> <li>Yes</li> <li>Yes</li> <li>Yes; Via CP and loadable FB</li> <li>180 byte; With PUT/GET</li> <li>240 byte; as server</li> </ul>
S5 compatible communication	
<ul style="list-style-type: none"> <li>• supported</li> </ul>	Yes; via CP and loadable FC
Number of connections	
<ul style="list-style-type: none"> <li>• overall</li> <li>• usable for PG communication <ul style="list-style-type: none"> <li>— reserved for PG communication</li> </ul> </li> </ul>	<ul style="list-style-type: none"> <li>12</li> <li>11</li> <li>1</li> </ul>

— adjustable for PG communication, min.	1
— adjustable for PG communication, max.	11
● usable for OP communication	11
— reserved for OP communication	1
— adjustable for OP communication, min.	1
— adjustable for OP communication, max.	11
● usable for S7 basic communication	8
— reserved for S7 basic communication	0
— adjustable for S7 basic communication, min.	0
— adjustable for S7 basic communication, max.	8
<b>S7 message functions</b>	
Number of login stations for message functions, max.	12; Depending on the configured connections for PG/OP and S7 basic communication
Process diagnostic messages	Yes
simultaneously active Alarm_S blocks, max.	300
<b>Test commissioning functions</b>	
Status block	Yes; Up to 2 simultaneously
Single step	Yes
Number of breakpoints	4
<b>Status/control</b>	
● Status/control variable	Yes
● Variables	Inputs, outputs, memory bits, DB, times, counters
● Number of variables, max.	30
— of which status variables, max.	30
— of which control variables, max.	14
<b>Forcing</b>	
● Forcing	Yes
● Forcing, variables	Inputs, outputs
● Number of variables, max.	10
<b>Diagnostic buffer</b>	
● present	Yes
● Number of entries, max.	500
— adjustable	No
— of which powerfail-proof	100; Only the last 100 entries are retained
● Number of entries readable in RUN, max.	499
— adjustable	Yes; From 10 to 499
— preset	10
<b>Service data</b>	
● can be read out	Yes
<b>Ambient conditions</b>	
<b>Ambient temperature during operation</b>	
● min.	0 °C
● max.	60 °C
<b>Configuration</b>	
<b>Configuration software</b>	
● STEP 7	Yes; V5.2 SP1 or higher with HW update
<b>Programming</b>	
● Command set	see instruction list
● Nesting levels	8
● System functions (SFC)	see instruction list
● System function blocks (SFB)	see instruction list
<b>Programming language</b>	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— CFC	Yes
— GRAPH	Yes
— HiGraph®	Yes

Know-how protection	
• User program protection/password protection	Yes
• Block encryption	Yes; With S7 block Privacy
<b>Dimensions</b>	
Width	40 mm
Height	125 mm
Depth	130 mm
<b>Weights</b>	
Weight, approx.	280 g
<b>Classifications</b>	

	Version	Classification
eClass	14	27-24-22-07
eClass	12	27-24-22-07
eClass	9.1	27-24-22-07
eClass	9	27-24-22-07
eClass	8	27-24-22-07
eClass	7.1	27-24-22-07
eClass	6	27-24-22-07
ETIM	10	EC000236
ETIM	9	EC000236
ETIM	8	EC000236
ETIM	7	EC000236
IDEA	4	3565
UNSPSC	15	32-15-17-05

**Approvals / Certificates**

General Product Approval



[Miscellaneous](#)



[Confirmation](#)



**other**      **Environment**



[Confirmation](#)

[Environmental Con-  
firmations](#)

[Environmental Con-  
firmations](#)



last modified:

4/7/2025