



*** spare part *** SIMATIC DP, CPU 1510SP F-1 PN for ET 200SP, central processing unit with work memory 150 KB for program and 750 KB for data, 1st interface: PROFINET IRT with 3-port switch, 72 ns bit performance, SIMATIC Memory Card required, BusAdapter required for port 1 and 2

| General information | |
|--|---|
| Product type designation | CPU 1510SP F-1 PN |
| HW functional status | FS05 |
| Firmware version | V2.9 |
| Product function | |
| <ul style="list-style-type: none"> I&M data | Yes; I&M0 to I&M3 |
| <ul style="list-style-type: none"> Module swapping during operation (hot swapping) | Yes; Multi-hot swapping |
| <ul style="list-style-type: none"> Isochronous mode | Yes; Only with PROFINET; with minimum OB 6x cycle of 625 µs |
| Engineering with | |
| <ul style="list-style-type: none"> STEP 7 TIA Portal configurable/integrated from version | V17 (FW V2.9) / V13 SP1 Update 4 (FW V1.8) or higher |
| Configuration control | |
| via dataset | Yes |
| Control elements | |
| Mode selector switch | 1 |
| Supply voltage | |
| Rated value (DC) | 24 V |
| permissible range, lower limit (DC) | 19.2 V |
| permissible range, upper limit (DC) | 28.8 V |
| Reverse polarity protection | Yes |
| Mains buffering | |
| <ul style="list-style-type: none"> Mains/voltage failure stored energy time | 10 ms |
| Input current | |
| Current consumption (rated value) | 0.6 A |
| Current consumption, max. | 0.9 A |
| Inrush current, max. | 4.7 A; Rated value |
| I^2t | 0.14 A ² ·s |
| Power | |
| Infeed power to the backplane bus | 8.75 W |
| Power loss | |
| Power loss, typ. | 5.6 W |
| Memory | |
| Number of slots for SIMATIC memory card | 1 |
| SIMATIC memory card required | Yes |
| Work memory | |
| <ul style="list-style-type: none"> integrated (for program) | 150 kbyte |
| <ul style="list-style-type: none"> integrated (for data) | 750 kbyte |
| Load memory | |
| <ul style="list-style-type: none"> Plug-in (SIMATIC Memory Card), max. | 32 Gbyte |
| Backup | |

| | |
|---|---|
| • maintenance-free | Yes |
| CPU processing times | |
| for bit operations, typ. | 72 ns |
| for word operations, typ. | 86 ns |
| for fixed point arithmetic, typ. | 115 ns |
| for floating point arithmetic, typ. | 461 ns |
| CPU-blocks | |
| Number of elements (total) | 4 000; Blocks (OB, FB, FC, DB) and UDTs |
| DB | |
| • Number range | 1 ... 60 999; subdivided into: number range that can be used by the user: 1 ... 59 999, and number range of DBs created via SFC 86: 60 000 ... 60 999 |
| • Size, max. | 750 kbyte; For DBs with absolute addressing, the max. size is 64 KB |
| FB | |
| • Number range | 0 ... 65 535 |
| • Size, max. | 100 kbyte |
| FC | |
| • Number range | 0 ... 65 535 |
| • Size, max. | 100 kbyte |
| OB | |
| • Size, max. | 150 kbyte |
| • Number of free cycle OBs | 100 |
| • Number of time alarm OBs | 20 |
| • Number of delay alarm OBs | 20 |
| • Number of cyclic interrupt OBs | 20; With Failsafe, two RTGs with one "Cyclic interrupt OB" or one "Free cycle OB" (F-OB) each are possible |
| • Number of process alarm OBs | 50 |
| • Number of DPV1 alarm OBs | 3 |
| • Number of isochronous mode OBs | 1 |
| • Number of technology synchronous alarm OBs | 2 |
| • Number of startup OBs | 100 |
| • Number of asynchronous error OBs | 4 |
| • Number of synchronous error OBs | 2 |
| • Number of diagnostic alarm OBs | 1 |
| Nesting depth | |
| • per priority class | 24; Up to 8 possible for F-blocks |
| Counters, timers and their retentivity | |
| S7 counter | |
| • Number | 2 048 |
| Retentivity | |
| — adjustable | Yes |
| IEC counter | |
| • Number | Any (only limited by the main memory) |
| Retentivity | |
| — adjustable | Yes |
| S7 times | |
| • Number | 2 048 |
| Retentivity | |
| — adjustable | Yes |
| IEC timer | |
| • Number | Any (only limited by the main memory) |
| Retentivity | |
| — adjustable | Yes |
| Data areas and their retentivity | |
| Retentive data area (incl. timers, counters, flags), max. | 128 kbyte; Available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 88 KB |
| Flag | |
| • Size, max. | 16 kbyte |
| • Number of clock memories | 8; 8 clock memory bit, grouped into one clock memory byte |
| Data blocks | |
| • Retentivity adjustable | Yes |

| | |
|---|---|
| • Retentivity preset | No |
| Local data | |
| • per priority class, max. | 64 kbyte; max. 16 KB per block |
| Address area | |
| Number of IO modules | 1 024; max. number of modules / submodules |
| I/O address area | |
| • Inputs | 32 kbyte; All inputs are in the process image |
| • Outputs | 32 kbyte; All outputs are in the process image |
| per integrated IO subsystem | |
| — Inputs (volume) | 8 kbyte |
| — Outputs (volume) | 8 kbyte |
| per CM/CP | |
| — Inputs (volume) | 8 kbyte |
| — Outputs (volume) | 8 kbyte |
| Subprocess images | |
| • Number of subprocess images, max. | 32 |
| Address space per module | |
| • Address space per module, max. | 288 byte; For input and output data respectively |
| Address space per station | |
| • Address space per station, max. | 2 560 byte; for central inputs and outputs; depending on configuration; 2 048 bytes for ET 200SP modules + 512 bytes for ET 200AL modules |
| Hardware configuration | |
| Number of distributed IO systems | 32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link) |
| Number of DP masters | |
| • Via CM | 1 |
| Number of IO Controllers | |
| • integrated | 1 |
| • Via CM | 0 |
| Rack | |
| • Modules per rack, max. | 80; CPU + 64 modules + server module (mounting width max. 1 m) + 16 ET 200AL modules |
| • Quantity of operable ET 200SP modules, max. | 64 |
| • Quantity of operable ET 200AL modules, max. | 16 |
| • Number of lines, max. | 1 |
| PtP CM | |
| • Number of PtP CMs | the number of connectable PtP CMs is only limited by the number of available slots |
| Time of day | |
| Clock | |
| • Type | Hardware clock |
| • Backup time | 6 wk; At 40 °C ambient temperature, typically |
| • Deviation per day, max. | 10 s; Typ.: 2 s |
| Operating hours counter | |
| • Number | 16 |
| Clock synchronization | |
| • supported | Yes |
| • to DP, master | Yes; Via CM DP module |
| • on DP, device | Yes; Via CM DP module |
| • in AS, master | Yes |
| • in AS, device | Yes |
| • on Ethernet via NTP | Yes |
| Interfaces | |
| Number of PROFINET interfaces | 1 |
| Number of PROFIBUS interfaces | 1; Via CM DP module |
| Optical interface | No |
| 1. Interface | |
| Interface types | |
| • RJ 45 (Ethernet) | Yes; X1 P3; opt. X1 P1 and X1 P2 via BusAdapter BA 2x RJ45 |

| | |
|---|---|
| <ul style="list-style-type: none"> • Number of ports • integrated switch • BusAdapter (PROFINET) | <p>3; 1. Integr. + 2. via BusAdapter</p> <p>Yes</p> <p>Yes; compatible BusAdapters: BA 2x RJ45, BA 2x FC, BA 2x M12</p> |
| Protocols | |
| <ul style="list-style-type: none"> • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Open IE communication • Web server • Media redundancy | <p>Yes; IPv4</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes; Optionally also encrypted</p> <p>Yes</p> <p>Yes; MRP Automanager according to IEC 62439-2 Edition 2.0</p> |
| PROFINET IO Controller | |
| Services | |
| <ul style="list-style-type: none"> — PG/OP communication — Isochronous mode — Direct data exchange — IRT — PROFlenergy — Prioritized startup — Number of connectable IO Devices, max. — Of which IO devices with IRT, max. — Number of connectable IO Devices for RT, max. — of which in line, max. — Number of IO Devices that can be simultaneously activated/deactivated, max. — Number of IO Devices per tool, max. — Updating times | <p>Yes</p> <p>Yes</p> <p>Yes; Requirement: IRT and isochronous mode (MRPD optional)</p> <p>Yes</p> <p>Yes; per user program</p> <p>Yes; Max. 32 PROFINET devices</p> <p>64; In total, up to 256 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET</p> <p>64</p> <p>64</p> <p>64</p> <p>8; in total across all interfaces</p> <p>8</p> <p>The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data</p> |
| Update time for IRT | |
| <ul style="list-style-type: none"> — for send cycle of 250 µs — for send cycle of 500 µs — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 4 ms — With IRT and parameterization of "odd" send cycles | <p>250 µs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 µs of the isochronous OB is decisive</p> <p>500 µs to 8 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 µs of the isochronous OB is decisive</p> <p>1 ms to 16 ms</p> <p>2 ms to 32 ms</p> <p>4 ms to 64 ms</p> <p>Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs ... 3 875 µs)</p> |
| Update time for RT | |
| <ul style="list-style-type: none"> — for send cycle of 250 µs — for send cycle of 500 µs — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 4 ms | <p>250 µs to 128 ms</p> <p>500 µs to 256 ms</p> <p>1 ms to 512 ms</p> <p>2 ms to 512 ms</p> <p>4 ms to 512 ms</p> |
| PROFINET IO Device | |
| Services | |
| <ul style="list-style-type: none"> — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record | <p>Yes</p> <p>No</p> <p>Yes</p> <p>Yes; per user program</p> <p>Yes</p> <p>4</p> <p>Yes; per user program</p> <p>Yes; per user program</p> |
| 2. Interface | |
| Interface types | |
| <ul style="list-style-type: none"> • RS 485 • Number of ports | <p>Yes; Via CM DP module</p> <p>1</p> |
| Protocols | |

| | |
|---|--|
| • PROFIBUS DP master | Yes |
| • PROFIBUS DP device | Yes |
| • SIMATIC communication | Yes |
| PROFIBUS DP master | |
| • Number of connections, max. | 48; Of which 4 each reserved for ES and HMI |
| • max. number of DP devices | 125; In total, up to 256 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET |
| Services | |
| — PG/OP communication | Yes |
| — Equidistance | No |
| — Isochronous mode | No |
| — activation/deactivation of DP devices | Yes |
| Interface types | |
| RJ 45 (Ethernet) | |
| • 100 Mbps | Yes |
| • Autonegotiation | Yes |
| • Autocrossing | Yes |
| • Industrial Ethernet status LED | Yes |
| RS 485 | |
| • Transmission rate, max. | 12 Mbit/s |
| Protocols | |
| PROFIsafe | Yes; V2.4 / V2.6 |
| Number of connections | |
| • Number of connections, max. | 96; via integrated interfaces of the CPU and connected CPs / CMs |
| • Number of connections reserved for ES/HMI/web | 10 |
| • Number of connections via integrated interfaces | 64 |
| • Number of connections per CP/CM | 32 |
| • Number of S7 routing paths | 16 |
| Redundancy mode | |
| • H-Sync forwarding | Yes |
| Media redundancy | |
| — Media redundancy | Yes; only via BusAdapter |
| — MRP | Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager; MRP Client |
| — MRP interconnection, supported | Yes; as MRP ring node according to IEC 62439-2 Edition 3.0 |
| — MRPD | Yes; Requirement: IRT |
| — Switchover time on line break, typ. | 200 ms; For MRP, bumpless for MRPD |
| — Number of stations in the ring, max. | 50 |
| SIMATIC communication | |
| • PG/OP communication | Yes; encryption with TLS V1.3 pre-selected |
| • S7 routing | Yes |
| • Data record routing | Yes |
| • S7 communication, as server | Yes |
| • S7 communication, as client | Yes |
| • User data per job, max. | See online help (S7 communication, user data size) |
| Open IE communication | |
| • TCP/IP | Yes |
| — Data length, max. | 64 kbyte |
| — several passive connections per port, supported | Yes |
| • ISO-on-TCP (RFC1006) | Yes |
| — Data length, max. | 64 kbyte |
| • UDP | Yes |
| — Data length, max. | 2 kbyte; 1 472 bytes for UDP broadcast |
| — UDP multicast | Yes; Max. 5 multicast circuits |
| • DHCP | Yes |
| • DNS | Yes |
| • SNMP | Yes |
| • DCP | Yes |
| • LLDP | Yes |

| | |
|--|--|
| • Encryption | Yes; Optional |
| Web server | |
| • HTTP | Yes; Standard and user pages |
| • HTTPS | Yes; Standard and user pages |
| OPC UA | |
| • Runtime license required | Yes; "Small" license required |
| • OPC UA Client | Yes |
| — Application authentication | Yes |
| — Security policies | Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 |
| — User authentication | "anonymous" or by user name & password |
| — Number of connections, max. | 4 |
| — Number of nodes of the client interfaces, recommended max. | 1 000 |
| — Number of elements for one call of OPC-UA_NodeGetHandleList/OPC-UA_ReadList/OPC-UA_WriteList, max. | 300 |
| — Number of elements for one call of OPC-UA_NameSpaceGetIndexList, max. | 20 |
| — Number of elements for one call of OPC-UA_MethodGetHandleList, max. | 100 |
| — Number of simultaneous calls of the client instructions for session management, per connection, max. | 1 |
| — Number of simultaneous calls of the client instructions for data access, per connection, max. | 5 |
| — Number of registerable nodes, max. | 5 000 |
| — Number of registerable method calls of OPC-UA_MethodCall, max. | 100 |
| — Number of inputs/outputs when calling OPC-UA_MethodCall, max. | 20 |
| • OPC UA Server | Yes; Data access (read, write, subscribe), method call, custom address space |
| — Application authentication | Yes |
| — Security policies | Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 |
| — User authentication | "anonymous" or by user name & password |
| — GDS support (certificate management) | Yes |
| — Number of sessions, max. | 32 |
| — Number of accessible variables, max. | 50 000 |
| — Number of registerable nodes, max. | 10 000 |
| — Number of subscriptions per session, max. | 20 |
| — Sampling interval, min. | 100 ms |
| — Publishing interval, min. | 500 ms |
| — Number of server methods, max. | 20 |
| — Number of inputs/outputs per server method, max. | 20 |
| — Number of monitored items, recommended max. | 1 000; for 1 s sampling interval and 1 s send interval |
| — Number of server interfaces, max. | 10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace" |
| — Number of nodes for user-defined server interfaces, max. | 1 000 |
| • Alarms and Conditions | Yes |
| — Number of program alarms | 100 |
| — Number of alarms for system diagnostics | 50 |
| Further protocols | |
| • MODBUS | Yes; MODBUS TCP |
| S7 message functions | |
| Number of login stations for message functions, max. | 32 |
| Program alarms | Yes |
| Number of configurable program messages, max. | 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH |
| Number of loadable program messages in RUN, max. | 2 500 |
| Number of simultaneously active program alarms | |
| • Number of program alarms | 600 |

| | |
|---|---|
| • Number of alarms for system diagnostics | 100 |
| • Number of alarms for motion technology objects | 80 |
| Test commissioning functions | |
| Joint commission (Team Engineering) | Yes; Parallel online access possible for up to 5 engineering systems |
| Status block | Yes; Up to 8 simultaneously (in total across all ES clients) |
| Single step | No |
| Number of breakpoints | 8 |
| Status/control | |
| • Status/control variable | Yes; without fail-safe |
| • Variables | Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters |
| • Number of variables, max. | |
| — of which status variables, max. | 200; per job |
| — of which control variables, max. | 200; per job |
| Forcing | |
| • Forcing | Yes; without fail-safe |
| • Forcing, variables | Peripheral inputs/outputs |
| • Number of variables, max. | 200 |
| Diagnostic buffer | |
| • present | Yes |
| • Number of entries, max. | 1 000 |
| — of which powerfail-proof | 500 |
| Traces | |
| • Number of configurable Traces | 4; Up to 512 KB of data per trace are possible |
| Interrupts/diagnostics/status information | |
| Diagnostics indication LED | |
| • RUN/STOP LED | Yes |
| • ERROR LED | Yes |
| • MAINT LED | Yes |
| • Monitoring of the supply voltage (PWR-LED) | Yes |
| • Connection display LINK TX/RX | Yes |
| Supported technology objects | |
| Motion Control | Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool |
| • Number of available Motion Control resources for technology objects | 800 |
| • Required Motion Control resources | |
| — per speed-controlled axis | 40 |
| — per positioning axis | 80 |
| — per synchronous axis | 160 |
| — per external encoder | 80 |
| — per output cam | 20 |
| — per cam track | 160 |
| — per probe | 40 |
| • Positioning axis | |
| — Number of positioning axes at motion control cycle of 4 ms (typical value) | 5 |
| — Number of positioning axes at motion control cycle of 8 ms (typical value) | 10 |
| Controller | |
| • PID_Compact | Yes; Universal PID controller with integrated optimization |
| • PID_3Step | Yes; PID controller with integrated optimization for valves |
| • PID-Temp | Yes; PID controller with integrated optimization for temperature |
| Counting and measuring | |
| • High-speed counter | Yes |
| Standards, approvals, certificates | |
| Highest safety class achievable in safety mode | |
| • Performance level according to ISO 13849-1 | PLe |
| • SIL acc. to IEC 61508 | SIL 3 |
| Probability of failure (for service life of 20 years and repair time of 100 hours) | |
| — Low demand mode: PFDavg in accordance with | < 2.00E-05 |

SIL3

— High demand/continuous mode: PFH in accordance with SIL3

< 1.00E-09

Ambient conditions

Ambient temperature during operation

- horizontal installation, min. -25 °C; No condensation
- horizontal installation, max. 60 °C
- vertical installation, min. -25 °C; No condensation
- vertical installation, max. 50 °C

Altitude during operation relating to sea level

- Installation altitude above sea level, max. 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual

Configuration

Programming

Programming language

- LAD Yes; incl. failsafe
- FBD Yes; incl. failsafe
- STL Yes
- SCL Yes
- GRAPH Yes

Know-how protection

- User program protection/password protection Yes
- Copy protection Yes
- Block protection Yes

Access protection

- protection of confidential configuration data Yes
- Protection level: Write protection Yes
- Protection level: Read/write protection Yes
- Protection level: Write protection for Failsafe Yes
- Protection level: Complete protection Yes

Cycle time monitoring

- lower limit adjustable minimum cycle time
- upper limit adjustable maximum cycle time

Dimensions

| | |
|--------|--------|
| Width | 100 mm |
| Height | 117 mm |
| Depth | 75 mm |

Weights

| | |
|-----------------|-------|
| Weight, approx. | 310 g |
|-----------------|-------|

Classifications

| | Version | Classification |
|--------|---------|----------------|
| eClass | 14 | 27-24-26-07 |
| eClass | 12 | 27-24-26-07 |
| eClass | 9.1 | 27-24-26-07 |
| eClass | 9 | 27-24-26-07 |
| eClass | 8 | 27-24-26-07 |
| eClass | 7.1 | 27-24-26-07 |
| eClass | 6 | 27-24-26-07 |
| ETIM | 10 | EC001603 |
| ETIM | 9 | EC001603 |
| ETIM | 8 | EC001603 |
| ETIM | 7 | EC001603 |
| IDEA | 4 | 3565 |
| UNSPSC | 15 | 32-15-17-05 |

Approvals / Certificates

General Product Approval



EG-Konf.

[Manufacturer Declaration](#)

[Miscellaneous](#)



[Miscellaneous](#)

General Product Approval

For use in hazardous locations



RCM



[China RoHS](#)



UL

[CCC-Ex](#)

[EM](#)

For use in hazardous locations

Functional Safety



ATEX

[Type Examination Certificate](#)

[Miscellaneous](#)



IECEX

[CCC-Ex](#)

[TUEV](#)

Functional Safety

Maritime application

[Type Examination Certificate](#)



ABS



BUREAU VERITAS



DNV



LRS

[NK / Nippon Kaiji Kyokai](#)

Maritime application

other



RINA



RMRS

[CCS \(China Classification Society\)](#)

[KR \(Korean Register of Shipping\)](#)



Profibus

[PROFINET](#)

Industrial Communication



Profibus

[PROFINET](#)

last modified:

12/1/2025