



SIMATIC S7-1500 Failsafe Software Controller CPU 1507S F Single License f. 1 install., R-SW, SW and docum. on DVD, license key on USB flash drive, R-SW Class A, 6 languages (de,en,it,fr,es,zh), executable in Windows 7 and Windows 10; reference HW: SIMATIC IPC2x7E, IPC4x7E, IPC4x7D, IPC6x7E, IPC8x7E, IPC627D, IPC677D, IPC827D

| General information                                      |   |
|--|---|
| Product type designation                                 | CPU 1507S F   |
| Software version   | V21.9   |
| Product function   |   |
| • I&M data   | Yes; I&M0 to I&M3   |
| Engineering with   |   |
| • STEP 7 TIA Portal configurable/integrated from version | V17   |
| Configuration control                                    |   |
| via dataset  | Yes   |
| Memory   |   |
| SIMATIC memory card required                             | No; Use of the PC mass storage  |
| Work memory  |   |
| • integrated (for program)                               | 7.5 Mbyte   |
| • integrated (for data)                                  | 20 Mbyte  |
| • integrated (for CPU function library of CPU Runtime)   | 50 Mbyte  |
| Load memory  |   |
| • integrated (on PC mass storage)                        | 320 Mbyte   |
| Backup   |   |
| • with UPS   | Yes; all memory areas declared retentive  |
| • with non-volatile memory                               | Yes; Depending on PC hardware   |
| CPU processing times                                     |   |
| for bit operations, typ.                                 | 1 ns; On IPC427E, Intel Xeon processor  |
| for word operations, typ.                                | 2 ns; On IPC427E, Intel Xeon processor  |
| for fixed point arithmetic, typ.                         | 2 ns; On IPC427E, Intel Xeon processor  |
| for floating point arithmetic, typ.                      | 2 ns; On IPC427E, Intel Xeon processor  |
| CPU-blocks   |   |
| Number of elements (total)                               | 6 000; In addition to blocks such as DBs, FBs and FCs, UDTs, global constants, etc. are also regarded as elements |
| DB   |   |
| • Number, max.   | 5 999; Number range: 1 to 65535   |
| • Size, max.   | 16 Mbyte  |
| FB   |   |
| • Number, max.   | 5 998; Number range: 1 to 65535   |
| • Size, max.   | 1 024 kbyte   |
| FC   |   |
| • Number, max.   | 5 999; Number range: 1 to 65535   |
| • Size, max.   | 1 024 kbyte   |
| OB   |   |
| • Size, max.   | 1 024 kbyte   |

|  |   |
|--|---|
| • Number of free cycle OBs   | 100   |
| • Number of time alarm OBs   | 20  |
| • Number of delay alarm OBs  | 20  |
| • Number of cyclic interrupt OBs                                   | 20  |
| • Number of process alarm OBs                                      | 50  |
| • Number of DPV1 alarm OBs   | 3   |
| • Number of isochronous mode OBs                                   | 1   |
| • Number of technology synchronous alarm OBs                       | 2   |
| • Number of startup OBs  | 100   |
| • Number of asynchronous error OBs                                 | 4   |
| • Number of synchronous error OBs                                  | 2   |
| • Number of diagnostic alarm OBs                                   | 1   |
| <b>Nesting depth</b>   |   |
| • per priority class   | 24; Up to 8 possible for F-blocks   |
| <b>Counters, timers and their retentivity</b>                      |   |
| <b>S7 counter</b>  |   |
| • Number   | 2 048   |
| <b>Retentivity</b>   |   |
| — adjustable   | Yes   |
| <b>IEC counter</b>   |   |
| • Number   | Any (only limited by the main memory)   |
| <b>Retentivity</b>   |   |
| — adjustable   | Yes   |
| <b>S7 times</b>  |   |
| • Number   | 2 048   |
| <b>Retentivity</b>   |   |
| — adjustable   | Yes   |
| <b>IEC timer</b>   |   |
| • Number   | Any (only limited by the main memory)   |
| <b>Retentivity</b>   |   |
| — adjustable   | Yes   |
| <b>Data areas and their retentivity</b>                            |   |
| Retentive data area (incl. timers, counters, flags), max.          | 135 kbyte; on SIMATIC IPC227E, IPC277E, IPC427D, IPC477D, IPC427E, IPC477E, IPC627E, IPC677E; 35 KB on SIMATIC IPC627D, IPC677D and IPC827D |
| Extended retentive data area (incl. timers, counters, flags), max. | 20 Mbyte; When using PC mass storage for retentive data   |
| <b>Flag</b>  |   |
| • Size, max.   | 16 kbyte  |
| • Number of clock memories   | 8; in 1 memory byte   |
| <b>Data blocks</b>   |   |
| • Retentivity adjustable   | Yes   |
| • Retentivity preset   | No  |
| <b>Local data</b>  |   |
| • per priority class, max.   | 64 kbyte; max. 16 KB per block  |
| <b>Address area</b>  |   |
| Number of IO modules   | 8 192   |
| <b>I/O address area</b>  |   |
| • Inputs   | 32 kbyte  |
| • Outputs  | 32 kbyte  |
| <b>Subprocess images</b>   |   |
| • Number of subprocess images, max.                                | 32  |
| <b>Hardware configuration</b>                                      |   |
| Number of distributed IO systems                                   | 20  |
| <b>Number of DP masters</b>  |   |
| • via PC interfaces  | 1   |
| <b>Number of IO Controllers</b>                                    |   |
| • via PC interfaces  | 1; any combination of RT or IRT interfaces  |
| <b>Time of day</b>   |   |
| <b>Clock</b>   |   |

|   |   |
|---|---|
| • Type  | Software clock, synchronizable, no battery backup   |
| • Deviation per day, max.   | Depending on PC hardware  |
| <b>Operating hours counter</b>  |   |
| • Number  | 16  |
| <b>Clock synchronization</b>  |   |
| • supported   | Yes   |
| • to DP, master   | No  |
| • on Ethernet via NTP   | Yes   |
| • on Windows clock, device  | Yes   |
| <b>Interfaces</b>   |   |
| Number of interfaces  | 3   |
| Number of PROFINET interfaces   | 2; In case of I-Device configuration, only one PROFINET interface is supported  |
| Number of PROFIBUS interfaces   | 1   |
| <b>1. Interface</b>   |   |
| Interface type  | CP 1625   |
| Number of connections   | 128   |
| <b>Interface types</b>  |   |
| • RJ 45 (Ethernet)  | Yes   |
| — Transmission rate, max.   | 100 Mbit/s  |
| — Industrial Ethernet status LED  | Yes   |
| • Number of ports   | 2   |
| • integrated switch   | Yes   |
| <b>Protocols</b>  |   |
| • PROFINET IO Controller  | Yes   |
| • PROFINET IO Device  | Yes   |
| • SIMATIC communication   | Yes   |
| • Open IE communication   | Yes   |
| • Web server  | Yes   |
| <b>PROFINET IO Controller</b>   |   |
| <b>Services</b>   |   |
| — Isochronous mode  | Yes   |
| — Direct data exchange  | Yes; Requirement: IRT and isochronous mode (MRPD optional)  |
| — shortest clock pulse  | 500 µs  |
| — IRT   | Yes   |
| — PROFlenergy   | Yes   |
| — Prioritized startup   | Yes; max. 32 PROFINET devices; if you want to use the "Prioritized startup" functionality in STEP 7 for the PROFINET interface of the CPU, the CPU and the device must be separated by means of a switch (e.g. SCALANCE X205) or CP1625 |
| — Number of connectable IO Devices, max.                                      | 256   |
| — Of which IO devices with IRT, max.  | 64  |
| — Number of connectable IO Devices for RT, max.                               | 256   |
| — of which in line, max.  | 256   |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8   |
| — IO Devices changing during operation (partner ports), supported             | Yes; the CPU and changing IO devices must be separated by a switch (e.g. SCALANCE X205)   |
| — Number of IO Devices per tool, max.   | 8   |
| — Updating times  | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data  |
| <b>Update time for IRT</b>  |   |
| — for send cycle of 250 µs  | 250 µs to 4 ms  |
| — for send cycle of 500 µs  | 500 µs to 8 ms  |
| — for send cycle of 1 ms  | 1 ms to 16 ms   |
| — for send cycle of 2 ms  | 2 ms to 32 ms   |
| — for send cycle of 4 ms  | 4 ms to 64 ms   |
| — With IRT and parameterization of "odd" send cycles                          | Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs ... 3 875 µs)  |
| <b>Update time for RT</b>   |   |
| — for send cycle of 250 µs  | 250 µs to 128 ms  |

|   |   |
|---|---|
| — for send cycle of 500 µs  | 500 µs to 256 ms  |
| — for send cycle of 1 ms  | 1 ms to 512 ms  |
| — for send cycle of 2 ms  | 2 ms to 512 ms  |
| — for send cycle of 4 ms  | 4 ms to 512 ms  |
| <b>Address area</b>   |   |
| — Inputs, max.  | 8 kbyte   |
| — Outputs, max.   | 8 kbyte   |
| <b>PROFINET IO Device</b>   |   |
| <b>Services</b>   |   |
| — PG/OP communication   | Yes   |
| — Isochronous mode  | No  |
| — IRT   | Yes   |
| — PROFlenergy   | Yes   |
| — Prioritized startup   | Yes; if you want to use the "Prioritized startup" functionality in STEP 7 for the PROFINET interface of the CPU, the CPU and the device must be separated by means of a switch (e.g. SCALANCE X205)                           |
| — Shared device   | Yes   |
| — Number of IO Controllers with shared device, max.                           | 4   |
| — Asset management record   | Yes   |
| <b>2. Interface</b>   |   |
| Interface type  | Onboard PROFINET / IE interface X2/X3 of the SIMATIC IPC, Intel Springville i210T   |
| Number of connections   | 128   |
| <b>Interface types</b>  |   |
| • RJ 45 (Ethernet)  | Yes   |
| — Transmission rate, max.   | 100 Mbit/s  |
| — Industrial Ethernet status LED  | Yes   |
| • Number of ports   | 1   |
| • integrated switch   | No  |
| <b>Protocols</b>  |   |
| • PROFINET IO Controller  | Yes   |
| • PROFINET IO Device  | Yes   |
| • SIMATIC communication   | Yes   |
| • Open IE communication   | Yes   |
| • Web server  | Yes   |
| • Media redundancy  | No  |
| <b>PROFINET IO Controller</b>   |   |
| <b>Services</b>   |   |
| — Isochronous mode  | No  |
| — IRT   | No  |
| — PROFlenergy   | Yes   |
| — Prioritized startup   | Yes; max. 32 PROFINET devices; if you want to use the "Prioritized startup" functionality in STEP 7 for the PROFINET interface of the CPU, the CPU and the device must be separated by means of a switch (e.g. SCALANCE X205) |
| — Number of connectable IO Devices for RT, max.                               | 128   |
| — of which in line, max.  | 128   |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8   |
| — Number of IO Devices per tool, max.   | 8   |
| — Updating times  | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data  |
| <b>Address area</b>   |   |
| — Inputs, max.  | 8 kbyte   |
| — Outputs, max.   | 8 kbyte   |
| <b>PROFINET IO Device</b>   |   |
| <b>Services</b>   |   |
| — Isochronous mode  | No  |
| — IRT   | No  |
| — PROFlenergy   | Yes   |
| — Shared device   | Yes   |

|   |     |
|---|-----|
| — Number of IO Controllers with shared device, max. | 4   |
| — Asset management record                           | Yes |

### 3. Interface

|                             |  |
|-----------------------------|--|
| Interface type              | PROFIBUS with CP 5622, CP 5622 onboard |
| Number of connections       | 44                                     |
| Interface types             |  |
| • RS 485                    | Yes                                    |
| Protocols                   |  |
| • PROFIBUS DP master        | Yes                                    |
| • PROFIBUS DP device        | No                                     |
| • SIMATIC communication     | Yes; no PG/STEP 7 connection possible  |
| PROFIBUS DP master          |  |
| • max. number of DP devices | 64                                     |
| Services                    |  |
| — Equidistance              | No                                     |
| — Isochronous mode          | No                                     |
| Address area                |  |
| — Inputs, max.              | 8 kbyte                                |
| — Outputs, max.             | 8 kbyte                                |

### 4. Interface

|                             |                                       |
|-----------------------------|---------------------------------------|
| Interface type              | PROFIBUS with CP 5623                 |
| Number of connections       | 44                                    |
| Interface types             |                                       |
| • RS 485                    | Yes                                   |
| Protocols                   |                                       |
| • PROFIBUS DP master        | Yes                                   |
| • PROFIBUS DP device        | No                                    |
| • SIMATIC communication     | Yes; no PG/STEP 7 connection possible |
| PROFIBUS DP master          |                                       |
| • max. number of DP devices | 125                                   |
| Services                    |                                       |
| — Equidistance              | No                                    |
| — Isochronous mode          | No                                    |
| Address area                |                                       |
| — Inputs, max.              | 8 kbyte                               |
| — Outputs, max.             | 8 kbyte                               |

### Protocols

|   |   |
|---|---|
| PROFIsafe                                       | Yes   |
| Number of connections                           |   |
| • Number of connections, max.                   | 128   |
| • Number of connections reserved for ES/HMI/web | 10  |
| • Number of S7 routing paths                    | 16  |
| Redundancy mode                                 |   |
| Media redundancy                                |   |
| — MRP   | Yes   |
| — MRPD  | Yes; Requirement: IRT                           |
| — Switchover time on line break, typ.           | 200 ms; For MRP, bumpless for MRPD              |
| — Number of stations in the ring, max.          | 50  |
| SIMATIC communication                           |   |
| • PG/OP communication                           | Yes   |
| • S7 routing                                    | Yes   |
| • S7 communication, as server                   | Yes   |
| • S7 communication, as client                   | Yes   |
| • User data per job, max.                       | 64 kbyte; BSEND/BRCV: 64 KB; PUT/GET: 960 bytes |
| Open IE communication                           |   |
| • TCP/IP  | Yes   |
| — Data length, max.                             | 64 kbyte  |
| • ISO-on-TCP (RFC1006)                          | Yes   |
| — Data length, max.                             | 64 kbyte  |

|  |  |
|--|--|
| <ul style="list-style-type: none"> <li>• UDP <ul style="list-style-type: none"> <li>— Data length, max.</li> <li>— UDP multicast</li> </ul> </li> <li>• DHCP</li> <li>• DNS</li> <li>• SNMP</li> <li>• DCP</li> <li>• LLDP</li> </ul>  | <p>Yes</p> <p>2 kbyte</p> <p>Yes; 128 multicast circuits (of which max. 5 via CP 1625)</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p>  |
| <b>Web server</b>  |  |
| <ul style="list-style-type: none"> <li>• HTTP</li> <li>• HTTPS</li> </ul>  | <p>Yes</p> <p>Yes</p>  |
| <b>OPC UA</b>  |  |
| <ul style="list-style-type: none"> <li>• Runtime license required</li> <li>• OPC UA Client <ul style="list-style-type: none"> <li>— Application authentication</li> <li>— Security policies</li> <li>— User authentication</li> <li>— Number of connections, max.</li> <li>— Number of nodes of the client interfaces, recommended max.</li> <li>— Number of elements for one call of OPC-UA_NodeGetHandleList/OPC-UA_ReadList/OPC-UA_WriteList, max.</li> <li>— Number of elements for one call of OPC-UA_NameSpaceGetIndexList, max.</li> <li>— Number of elements for one call of OPC-UA_MethodGetHandleList, max.</li> <li>— Number of simultaneous calls of the client instructions for session management, per connection, max.</li> <li>— Number of simultaneous calls of the client instructions for data access, per connection, max.</li> <li>— Number of registerable nodes, max.</li> <li>— Number of registerable method calls of OPC-UA_MethodCall, max.</li> <li>— Number of inputs/outputs when calling OPC-UA_MethodCall, max.</li> </ul> </li> <li>• OPC UA Server <ul style="list-style-type: none"> <li>— Application authentication</li> <li>— Security policies</li> <li>— User authentication</li> <li>— Number of sessions, max.</li> <li>— Number of accessible variables, max.</li> <li>— Number of registerable nodes, max.</li> <li>— Number of subscriptions per session, max.</li> <li>— Sampling interval, min.</li> <li>— Publishing interval, min.</li> <li>— Number of server methods, max.</li> <li>— Number of inputs/outputs per server method, max.</li> <li>— Number of monitored items, recommended max.</li> <li>— Number of server interfaces, max.</li> <li>— Number of nodes for user-defined server interfaces, max.</li> </ul> </li> </ul> | <p>Yes; "Medium" license required</p> <p>Yes; Data access (read, write), method call</p> <p>Yes</p> <p>Yes; Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256</p> <p>Yes; "anonymous" or by user name &amp; password</p> <p>40</p> <p>5 000</p> <p>300</p> <p>20</p> <p>100</p> <p>1</p> <p>5</p> <p>5 000</p> <p>100</p> <p>20</p> <p>Yes; Data access (read, write, subscribe), method call, custom address space</p> <p>Yes</p> <p>Yes; Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256</p> <p>Yes; "anonymous" or by user name &amp; password</p> <p>64</p> <p>200 000</p> <p>50 000</p> <p>20</p> <p>10 ms</p> <p>10 ms</p> <p>100</p> <p>20</p> <p>10 000; for 1 s sampling interval and 1 s send interval</p> <p>10</p> <p>30 000</p> |
| <b>Further protocols</b>   |  |
| <ul style="list-style-type: none"> <li>• MODBUS</li> </ul>   | <p>Yes; MODBUS TCP</p>   |
| <b>S7 message functions</b>  |  |
| Number of login stations for message functions, max.   | 32   |
| Program alarms   | Yes  |
| Number of configurable program messages, max.  | 10 000   |
| Number of loadable program messages in RUN, max.   | 5 000  |
| Number of simultaneously active program alarms   | 1 000  |

|   |  |
|---|--|
| <ul style="list-style-type: none"> <li>• Number of program alarms</li> </ul>  | 1 000  |
| <ul style="list-style-type: none"> <li>• Number of alarms for system diagnostics</li> </ul>                             | 200  |
| <ul style="list-style-type: none"> <li>• Number of alarms for motion technology objects</li> </ul>                      | 160  |
| <b>Test commissioning functions</b>   |  |
| Joint commission (Team Engineering)   | Yes; Parallel online access possible for up to 10 engineering systems  |
| Status block  | Yes; up to 8 simultaneously  |
| Single step   | Yes  |
| Number of breakpoints   | 8  |
| <b>Status/control</b>   |  |
| <ul style="list-style-type: none"> <li>• Status/control variable</li> </ul>   | Yes  |
| <ul style="list-style-type: none"> <li>• Variables</li> </ul>   | Inputs, outputs, memory bits, DB, times, counters  |
| <ul style="list-style-type: none"> <li>• Number of variables, max.</li> </ul>   |  |
| — of which status variables, max.   | 200  |
| — of which control variables, max.  | 200  |
| <b>Forcing</b>  |  |
| <ul style="list-style-type: none"> <li>• Forcing</li> </ul>   | Yes  |
| <ul style="list-style-type: none"> <li>• Forcing, variables</li> </ul>  | Inputs, outputs  |
| <ul style="list-style-type: none"> <li>• Number of variables, max.</li> </ul>   | 200  |
| <b>Diagnostic buffer</b>  |  |
| <ul style="list-style-type: none"> <li>• present</li> </ul>   | Yes  |
| <ul style="list-style-type: none"> <li>• Number of entries, max.</li> </ul>   | 1 000  |
| — of which powerfail-proof  | 300  |
| <b>Traces</b>   |  |
| <ul style="list-style-type: none"> <li>• Number of configurable Traces</li> </ul>                                       | 4  |
| <ul style="list-style-type: none"> <li>• Memory size per trace, max.</li> </ul>   | 512 kbyte  |
| <b>Interrupts/diagnostics/status information</b>  |  |
| <b>Diagnostics indication LED</b>   |  |
| <ul style="list-style-type: none"> <li>• RUN/STOP LED</li> </ul>  | Yes; HW LED of SIMATIC IPC227E, IPC427D/E, IPC627D/E, IPC827D, IPC677D/E   |
| <ul style="list-style-type: none"> <li>• ERROR LED</li> </ul>   | Yes; HW LED of SIMATIC IPC227E, IPC427D/E, IPC627D/E, IPC826D, IPC677D/E   |
| <ul style="list-style-type: none"> <li>• MAINT LED</li> </ul>   | Yes; HW LED of SIMATIC IPC227E, IPC427D/E, IPC627D/E, IPC826D, IPC677D/E   |
| <b>Supported technology objects</b>   |  |
| Motion Control  | Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool or SIZER |
| <ul style="list-style-type: none"> <li>• Number of available Motion Control resources for technology objects</li> </ul> | 4 800  |
| <ul style="list-style-type: none"> <li>• Required Motion Control resources</li> </ul>                                   |  |
| — per speed-controlled axis   | 40   |
| — per positioning axis  | 80   |
| — per synchronous axis  | 160  |
| — per external encoder  | 80   |
| — per output cam  | 20   |
| — per cam track   | 160  |
| — per probe   | 40   |
| <ul style="list-style-type: none"> <li>• Positioning axis</li> </ul>  |  |
| — Number of positioning axes at motion control cycle of 4 ms (typical value)  | 30; On IPC427E, Intel Xeon processor   |
| — Number of positioning axes at motion control cycle of 8 ms (typical value)  | 60; On IPC427E, Intel Xeon processor   |
| <b>Controller</b>   |  |
| <ul style="list-style-type: none"> <li>• PID_Compact</li> </ul>   | Yes; Universal PID controller with integrated optimization   |
| <ul style="list-style-type: none"> <li>• PID_3Step</li> </ul>   | Yes; PID controller with integrated optimization for valves  |
| <ul style="list-style-type: none"> <li>• PID-Temp</li> </ul>  | Yes; PID controller with integrated optimization for temperature   |
| <b>Counting and measuring</b>   |  |
| <ul style="list-style-type: none"> <li>• High-speed counter</li> </ul>  | Yes  |
| <b>Standards, approvals, certificates</b>   |  |
| <b>Highest safety class achievable in safety mode</b>   |  |
| <ul style="list-style-type: none"> <li>• Performance level according to ISO 13849-1</li> </ul>                          | PLe  |
| <ul style="list-style-type: none"> <li>• SIL acc. to IEC 61508</li> </ul>   | SIL 3  |

|  |            |
|--|------------|
| Probability of failure (for service life of 20 years and repair time of 100 hours) |            |
| — Low demand mode: PFDavg in accordance with SIL3                                  | < 2.00E-05 |
| — High demand/continuous mode: PFH in accordance with SIL3                         | < 1.00E-09 |

### Hardware requirement

|                   |   |
|-------------------|---|
| Hardware required | SIMATIC IPC2x7E, IPC4x7D/E, IPC627D, IPC677D, IPC827D: configurations with NVRAM required; IPC6x7E, IPC8x7E |
|-------------------|---|

|  |  |
|--|--|
| Processor                                    |  |
| • Single-core processor                      | No   |
| • Single-core processor with hyper-threading | No   |
| • Multi-core processor                       | Yes  |
| • Multi-core processor with hyper-threading  | Yes  |
| • occupied cores                             | 1; For multicore processors with activated Hyper-Threading, one complete physical core is reserved for the CPU 1507S |

|   |           |
|---|-----------|
| Memory  |           |
| • Work memory, min.                           | 4 Gbyte   |
| • Hard disk memory required for installation  | 720 Mbyte |
| • Temporary hard disk memory for installation | 230 Mbyte |
| • Hard disk memory required at runtime        | 400 Mbyte |

### Operating systems

|                             |  |
|-----------------------------|--|
| Runs under operating system |  |
| • Windows 7                 | Yes; Professional, Enterprise, Ultimate (32 bit and 64 bit); Windows Embedded Standard 7 with delivery image of the SIMATIC IPC  |
| • Windows 10                | Yes; Windows 10 Enterprise 2016 LTSC, 64-bit, MUI on IPC2x7E, IPC4x7E, IPC6x7D, IPC8x7D; Windows 10 Enterprise 2019 LTSC 64-bit, MUI on IPC2x7E, IPC4x7E, IPC6x7E, IPC8x7E |

### Configuration

|                      |                     |
|----------------------|---------------------|
| Programming          |                     |
| Programming language |                     |
| — LAD                | Yes; incl. failsafe |
| — FBD                | Yes; incl. failsafe |
| — STL                | Yes                 |
| — SCL                | Yes                 |
| — CFC                | No                  |
| — GRAPH              | Yes                 |

|   |     |
|---|-----|
| Know-how protection                           |     |
| • User program protection/password protection | Yes |
| • Copy protection                             | Yes |
| • Block protection                            | Yes |

|   |     |
|---|-----|
| Access protection                                 |     |
| • Protection level: Write protection              | Yes |
| • Protection level: Read/write protection         | Yes |
| • Protection level: Write protection for Failsafe | Yes |
| • Protection level: Complete protection           | Yes |

|                       |                               |
|-----------------------|-------------------------------|
| Cycle time monitoring |                               |
| • lower limit         | adjustable minimum cycle time |
| • upper limit         | adjustable maximum cycle time |

|                             |           |
|-----------------------------|-----------|
| Open Development interfaces |           |
| • Size of ODK SO file, max. | 9.8 Mbyte |

### Classifications

|        | Version | Classification |
|--------|---------|----------------|
| eClass | 14      | 27-24-06-03    |
| eClass | 12      | 27-24-06-03    |
| eClass | 9.1     | 27-24-06-03    |
| eClass | 9       | 27-24-06-03    |
| eClass | 8       | 27-24-06-03    |
| eClass | 7.1     | 27-24-06-03    |
| eClass | 6       | 27-24-06-03    |

|        |    |             |
|--------|----|-------------|
| ETIM   | 10 | EC002633    |
| ETIM   | 9  | EC002633    |
| ETIM   | 8  | EC002633    |
| ETIM   | 7  | EC002633    |
| IDEA   | 4  | 3580        |
| UNSPSC | 15 | 32-15-17-07 |

**Approvals / Certificates**

|                                 |                          |
|---------------------------------|--------------------------|
| <b>General Product Approval</b> | <b>Functional Safety</b> |
|---------------------------------|--------------------------|



[Type Examination Certificate](#)

|                          |              |
|--------------------------|--------------|
| <b>Test Certificates</b> | <b>other</b> |
|--------------------------|--------------|

[Miscellaneous](#)

[Type Test Certificates/Test Report](#)

[Special Test Certificate](#)

[Miscellaneous](#)



[Confirmation](#)

|                |                    |
|----------------|--------------------|
| <b>Railway</b> | <b>Environment</b> |
|----------------|--------------------|

[Special Test Certificate](#)

[Environmental Confirmations](#)

last modified:

12/8/2024