

SIMATIC S7-1500, Software Controller CPU 1508S, Single License for 1 installation, runtime software class A; R-SW, software and documentation on DVD, license key on USB flash drive; 6 languages (de,en,it,fr,es,zh); executable in Windows 10; reference hardware: IPC4x7E, BX/PX-39A, IPC6x7E, IPC8x7E

General information	
Product type designation	CPU 1508S
Software version	V31.1
Product function	
<ul style="list-style-type: none"> I&M data SysLog 	Yes; I&M0 to I&M3 Yes
Engineering with	
<ul style="list-style-type: none"> STEP 7 TIA Portal configurable/integrated from version 	V20
Configuration control	
via dataset	Yes
Memory	
SIMATIC memory card required	No; Use of the PC mass storage
Work memory	
<ul style="list-style-type: none"> integrated (for program) integrated (for data) integrated (for CPU function library of CPU Runtime) 	10 Mbyte 100 Mbyte 50 Mbyte
Load memory	
<ul style="list-style-type: none"> integrated (on PC mass storage) 	1 024 Mbyte
Backup	
<ul style="list-style-type: none"> with UPS with non-volatile memory 	Yes; all memory areas declared retentive Yes; Depending on PC hardware
CPU processing times	
for bit operations, typ.	1 ns; On IPC427E, Intel Xeon processor
for word operations, typ.	2 ns; On IPC427E, Intel Xeon processor
for fixed point arithmetic, typ.	2 ns; On IPC427E, Intel Xeon processor
for floating point arithmetic, typ.	2 ns; On IPC427E, Intel Xeon processor
CPU-blocks	
Number of elements (total)	20 000; blocks (OB, FB, FC, DB), UDTs and global constants
DB	
<ul style="list-style-type: none"> Number, max. Size, max. 	19 999; Number range: 1 to 65535 16 Mbyte
FB	
<ul style="list-style-type: none"> Number, max. Size, max. 	19 998; Number range: 1 to 65535 1 024 kbyte
FC	
<ul style="list-style-type: none"> Number, max. Size, max. 	19 999; Number range: 1 to 65535 1 024 kbyte
OB	
<ul style="list-style-type: none"> Size, max. Number of free cycle OBs Number of time alarm OBs Number of delay alarm OBs Number of cyclic interrupt OBs Number of process alarm OBs Number of DPV1 alarm OBs Number of isochronous mode OBs Number of technology synchronous alarm OBs Number of startup OBs 	1 024 kbyte 100 20 20 20 50 3 1 2 100

• Number of asynchronous error OBs	4
• Number of synchronous error OBs	2
• Number of diagnostic alarm OBs	1
Nesting depth	
• per priority class	24
Counters, timers and their retentivity	
S7 counter	
• Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
• Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
• Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
• Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	135 kbyte; on SIMATIC IPC with NVRAM option
Extended retentive data area (incl. timers, counters, flags), max.	100 Mbyte; When using PC mass storage for retentive data
Flag	
• Size, max.	16 kbyte
• Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
• Retentivity adjustable	Yes
• Retentivity preset	No
Local data	
• per priority class, max.	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	8 192
I/O address area	
• Inputs	32 kbyte
• Outputs	32 kbyte
Subprocess images	
• Number of subprocess images, max.	32
Hardware configuration	
Number of distributed IO systems	20
Number of IO Controllers	
• via PC interfaces	2; any combination of RT or IRT interfaces
Time of day	
Clock	
• Type	Software clock, synchronizable, no battery backup
• Deviation per day, max.	Depending on PC hardware
Operating hours counter	
• Number	16
Clock synchronization	
• supported	Yes
• to DP, master	No
• on Ethernet via NTP	Yes
• on Windows clock, device	Yes
Interfaces	
Number of interfaces	3
Number of PROFINET interfaces	2
Number of PROFIBUS interfaces	0

1. Interface	
Interface type	CP 1625
Number of connections	192
Interface types	
<ul style="list-style-type: none"> ● RJ 45 (Ethernet) <ul style="list-style-type: none"> — Transmission rate, max. — Industrial Ethernet status LED ● Number of ports ● integrated switch 	<ul style="list-style-type: none"> Yes 100 Mbit/s Yes 2 Yes
Protocols	
<ul style="list-style-type: none"> ● IP protocol ● PROFINET IO Controller ● PROFINET IO Device ● SIMATIC communication ● Open IE communication ● Web server ● Media redundancy 	<ul style="list-style-type: none"> Yes; IPv4 Yes Yes Yes Yes; Optionally also encrypted Yes Yes; MRP Automanager according to IEC 62439-2 Edition 2.0
PROFINET IO Controller	
Services	
<ul style="list-style-type: none"> — Isochronous mode — Direct data exchange — shortest clock pulse — IRT — PROFIenergy — Prioritized startup — Number of connectable IO Devices, max. — Of which IO devices with IRT, max. — Number of connectable IO Devices for RT, max. — of which in line, max. — Number of IO Devices that can be simultaneously activated/deactivated, max. — IO Devices changing during operation (partner ports), supported — Number of IO Devices per tool, max. — Updating times — PROFINET Security Class 	<ul style="list-style-type: none"> Yes Yes; Requirement: IRT and isochronous mode (MRPD optional) 500 µs Yes Yes Yes; max. 32 PROFINET devices; if you want to use the "Prioritized startup" functionality in STEP 7 for the PROFINET interface of the CPU, the CPU and the device must be separated by means of a switch (e.g SCALANCE X205) or CP1625 256; the maximal amount of supported devices on all interfaces (PN/PB) is 384 (256+128) in total; theoretically it should be 509 (256+128+125), but it is accepted to be limited to 384 64 256 256 8 Yes; the CPU and changing IO devices must be separated by a switch (e.g. SCALANCE X205) 8 The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data 1
Update time for IRT	
<ul style="list-style-type: none"> — for send cycle of 250 µs — for send cycle of 500 µs — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 4 ms — With IRT and parameterization of "odd" send cycles 	<ul style="list-style-type: none"> 250 µs to 4 ms 500 µs to 8 ms 1 ms to 16 ms 2 ms to 32 ms Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs ... 3 875 µs) Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs ... 3 875 µs)
Update time for RT	
<ul style="list-style-type: none"> — for send cycle of 250 µs — for send cycle of 500 µs — for send cycle of 1 ms — for send cycle of 2 ms — for send cycle of 4 ms 	<ul style="list-style-type: none"> 250 µs to 128 ms 500 µs to 256 ms 1 ms to 512 ms 2 ms to 512 ms 4 ms to 512 ms
Address area	
<ul style="list-style-type: none"> — Inputs, max. — Outputs, max. 	<ul style="list-style-type: none"> 16 kbyte 16 kbyte
PROFINET IO Device	

Services	
— Isochronous mode	No
— IRT	Yes
— PROFINergy	Yes
— Prioritized startup	Yes
— Shared device	Yes
— Number of IO Controllers with shared device, max.	4
— Asset management record	Yes
— PROFINET Security Class	SNMP Configuration and DCP Read Only
2. Interface	
Interface type	Onboard PROFINET / IE interface X2 of the SIMATIC IPC, Intel Springville i210T
Number of connections	192
Interface types	
• RJ 45 (Ethernet)	Yes
— Transmission rate, max.	100 Mbit/s
— Industrial Ethernet status LED	Yes
• Number of ports	1
• integrated switch	No
Protocols	
• IP protocol	Yes; IPv4
• PROFINET IO Controller	Yes
• PROFINET IO Device	Yes
• PROFIBUS DP master	No
• PROFIBUS DP device	No
• SIMATIC communication	Yes
• Open IE communication	Yes
• Web server	Yes
• Media redundancy	No
PROFINET IO Controller	
Services	
— Isochronous mode	No
— IRT	No
— PROFINergy	Yes
— Prioritized startup	Yes; max. 32 PROFINET devices; if you want to use the "Prioritized startup" functionality in STEP 7 for the PROFINET interface of the CPU, the CPU and the device must be separated by means of a switch (e.g. SCALANCE X205)
— Number of connectable IO Devices for RT, max.	128; the maximal amount of supported devices on all interfaces (PN/PB) is 384 (256+128) in total; theoretically it should be 509 (256+128+125), but it is accepted to be limited to 384
— of which in line, max.	128
— Number of IO Devices that can be simultaneously activated/deactivated, max.	8
— Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
— PROFINET Security Class	1
Address area	
— Inputs, max.	8 kbyte
— Outputs, max.	8 kbyte
PROFINET IO Device	
Services	
— Isochronous mode	No
— IRT	No
— PROFINergy	Yes
— Shared device	Yes
— Number of IO Controllers with shared device, max.	4
— Asset management record	Yes
— PROFINET Security Class	SNMP Configuration and DCP Read Only
Protocols	

PROFIsafe	No
Number of connections	
• Number of connections, max.	192
• Number of connections reserved for ES/HMI/web	10
• Number of S7 routing paths	16
Redundancy mode	
Media redundancy	
— MRP	Yes
— MRPD	Yes; Requirement: IRT
— Switchover time on line break, typ.	200 ms; For MRP, bumpless for MRPD
— Number of stations in the ring, max.	50
SIMATIC communication	
• PG/OP communication	Yes
• S7 routing	Yes
• S7 communication, as server	Yes
• S7 communication, as client	Yes
• User data per job, max.	64 kbyte; BSEND/BRCV: 64 KB; PUT/GET: 960 bytes
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte
— UDP multicast	Yes; 128 multicast circuits (of which max. 5 via CP 1625)
• DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	
• Runtime license required	Yes; "Large" license required
• OPC UA Client	Yes; Data access (read, write), method call
— Security policies	Yes; Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	Yes; "anonymous" or by user name & password
— Number of connections, max.	40
— Number of nodes of the client interfaces, recommended max.	5 000
— Number of elements for one call of OPC-UA_NodeGetHandleList/OPC-UA_ReadList/OPC-UA_WriteList, max.	300
— Number of elements for one call of OPC-UA_NameSpaceGetIndexList, max.	20
— Number of elements for one call of OPC-UA_MethodGetHandleList, max.	100
— Number of simultaneous calls of the client instructions for session management, per connection, max.	1
— Number of simultaneous calls of the client instructions for data access, per connection, max.	5
— Number of registerable nodes, max.	5 000
— Number of registerable method calls of OPC-UA_MethodCall, max.	100
— Number of inputs/outputs when calling OPC-UA_MethodCall, max.	20
• OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space
— Application authentication	Yes
— Security policies	Yes; Available security policies: None, Basic128Rsa15, Basic256Rsa15,

— User authentication	Basic256Sha256
— GDS support (certificate management)	Yes; "anonymous" or by user name & password
— Number of sessions, max.	Yes
— Number of accessible variables, max.	64
— Number of registerable nodes, max.	200 000
— Number of subscriptions per session, max.	50 000
— Sampling interval, min.	50
— Publishing interval, min.	10 ms
— Number of server methods, max.	10 ms
— Number of inputs/outputs per server method, max.	100
— Number of monitored items, recommended max.	20
— Number of server interfaces, max.	10 000; for 1 s sampling interval and 1 s send interval
— Number of nodes for user-defined server interfaces, max.	10
• Alarms and Conditions	30 000
— Number of program alarms	400
— Number of alarms for system diagnostics	200
Further protocols	
• MODBUS	Yes; MODBUS TCP
S7 message functions	
Number of login stations for message functions, max.	32
Program alarms	Yes
Number of configurable program messages, max.	10 000
Number of loadable program messages in RUN, max.	5 000
Number of simultaneously active program alarms	1 000
• Number of program alarms	1 000
• Number of alarms for system diagnostics	200
• Number of alarms for motion technology objects	160
Test commissioning functions	
Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 10 engineering systems
Status block	Yes; up to 8 simultaneously
Single step	Yes
Number of breakpoints	8
Status/control	
• Status/control variable	Yes
• Variables	Inputs, outputs, memory bits, DB, times, counters
• Number of variables, max.	
— of which status variables, max.	200; per job
— of which control variables, max.	200; per job
Forcing	
• Forcing	Yes
• Forcing, variables	Inputs, outputs
• Number of variables, max.	200
Diagnostic buffer	
• present	Yes
• Number of entries, max.	1 000
— of which powerfail-proof	300
Traces	
• Number of configurable Traces	4
• Memory size per trace, max.	512 kbyte
Interrupts/diagnostics/status information	
Diagnostics indication LED	
• RUN/STOP LED	Yes; HW LED of SIMATIC IPC427E, IPC BX-39A, IPC627E
• ERROR LED	Yes; HW LED of SIMATIC IPC427E, IPC BX-39A, IPC627E
• MAINT LED	Yes; HW LED of SIMATIC IPC427E, IPC BX-39A, IPC627E
Supported technology objects	
Motion Control	Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool or SIZER

<ul style="list-style-type: none"> • Number of available Motion Control resources for technology objects 	4 800
<ul style="list-style-type: none"> • Required Motion Control resources <ul style="list-style-type: none"> — per speed-controlled axis — per positioning axis — per synchronous axis — per external encoder — per output cam — per cam track — per probe 	40 80 160 80 20 160 40
<ul style="list-style-type: none"> • Positioning axis <ul style="list-style-type: none"> — Number of positioning axes at motion control cycle of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value) 	30; On IPC427E, Intel Xeon processor 60; On IPC427E, Intel Xeon processor
Controller <ul style="list-style-type: none"> • PID_Compact • PID_3Step • PID-Temp 	Yes; Universal PID controller with integrated optimization Yes; PID controller with integrated optimization for valves Yes; PID controller with integrated optimization for temperature
Counting and measuring <ul style="list-style-type: none"> • High-speed counter 	Yes
Hardware requirement	
Hardware required	SIMATIC IPC427E, IPC477E (Pro), IPC BX-39A, IPC PX-39A (Pro), IPC627E, IPC677E, IPC647E, IPC847E
Processor	
<ul style="list-style-type: none"> • Single-core processor • Single-core processor with hyper-threading • Multi-core processor • Multi-core processor with hyper-threading • occupied cores 	No No Yes Yes 1; For multicore processors with activated Hyper-Threading, one complete physical core is reserved for the CPU 1507S
Memory	
<ul style="list-style-type: none"> • Work memory, min. • Hard disk memory required for installation • Temporary hard disk memory for installation • Hard disk memory required at runtime 	8 Gbyte 720 Mbyte 230 Mbyte 1 661 Mbyte
Operating systems	
Runs under operating system <ul style="list-style-type: none"> • Windows 7 • Windows 10 • Linux 	No Yes; Windows 10 Enterprise 2019 LTSC and 2021 LTSC, 64-bit, MUI No
Configuration	
Programming	
Programming language <ul style="list-style-type: none"> — LAD — FBD — STL — SCL — CFC — GRAPH 	Yes Yes Yes Yes Yes Yes
Know-how protection	
<ul style="list-style-type: none"> • User program protection/password protection • Copy protection • Block protection 	Yes Yes Yes
Access protection	
<ul style="list-style-type: none"> • protection of confidential configuration data • Protection level: Write protection • Protection level: Read/write protection • Protection level: Complete protection • User administration 	Yes Yes Yes Yes Yes

• Number of users	100
Cycle time monitoring	
• lower limit	adjustable minimum cycle time
• upper limit	adjustable maximum cycle time
Open Development interfaces	
• Size of ODK SO file, max.	9.8 Mbyte

Classifications

	Version	Classification
eClass	14	27-24-06-03
eClass	12	27-24-06-03
eClass	9.1	27-24-06-03
eClass	9	27-24-06-03
eClass	8	27-24-06-03
eClass	7.1	27-24-06-03
eClass	6	27-24-06-03
ETIM	10	EC002633
ETIM	9	EC002633
ETIM	8	EC002633
ETIM	7	EC002633

Approvals / Certificates

General Product Approval

[TUEV](#)

last modified:

1/13/2025 